

Project Name	Alief ISD Restroom Renovations	Prepared By	DLR Group
Date	3/2/2026	Project No.	39-25156-00
Purpose	RFI Log		
Location	Alief ISD – Elsie HS, Heflin ES, Alief MS, Smith ES, Boone ES, and Rees ES		

RFIs:

1. **QUESTION:** Heflin ES – Men A108 / Women A109 – Drawing A2.1: The RCP indicates an 8'-0" ceiling height; however, the elevations show tile installed up to 9'-8". Please clarify this discrepancy.
RESPONSE: The ceilings are at 8'-0" above finished floor. Please see attached ADDENDA
2. **QUESTION:** Per the elevations for Boone ES (A2.3–A2.6), not all restroom walls are indicated to receive tile. Please confirm that the tile will be installed only on the walls shown in the elevations.
RESPONSE: All walls in the restrooms are to receive tile up to the ceilings. Please see attached ADDENDA.
3. **QUESTION:** Please confirm the specified finish for the Schluter trims.
RESPONSE: The color of the Schluter Trim for all schools is to be ACGB Brushed Chrome Anodized Aluminum.
4. **QUESTION:** The proposal form says to include a \$250,000 allowance. Is this correct? Earlier Q&A stated no allowances. Please advise.
RESPONSE: Include \$250,000.00 for allowance.
5. **QUESTION:** Referencing Sheet P.011 Demolition note 4, states UNLESS SPECIFICALLY NOTED OTHERWISE ON THE PLANS, WHERE EACH NEW WALL HUNG FIXTURE WILL BE PROVIDED AND WHERE EACH EXISTING WALL HUNG FIXTURE WILL BE RE-INSTALLED, A NEW CORRESPONDING FIXTURE CARRIER SHALL ALSO BE PROVIDED. THIS REQUIREMENT SHALL APPLY TO ONE-FOR-ONE FIXTURE REPLACEMENTS AND ALL ADJUSTMENTS TO WALL HUNG FIXTURE LOCATIONS AND FIXTURE HEIGHTS. ALL WORK ASSOCIATED WITH PROVIDING SUCH CARRIERS SHALL BE INCLUDED IN THE PROJECT SCOPE WITH NO EXCEPTIONS. Are new carriers actually required for all restrooms and all schools? If not, please select which ones need new carriers. This requires demoing the walls, tile, etc and going back with new. Since the duration is only 2 months this is really stretching the timeline of this project. Given the amount of carriers that would be needed. Please advise. Carrier notes apply on sheet P5.01 Plumbing Fixture Schedule as well. Please advise.
RESPONSE: New in wall plumbing Carriers for toilets /urinals/lavatory/drinking fountains are required for this project
6. **QUESTION:** Please confirm the liquidated damages, and attach the exhibit C A101-2017, Exhibit A to the AIA document A101-2017, Insurance and Bonds and A201-2017, all as amended by AISD
RESPONSE: Include \$1000/day until completion. Please see attached A101-2017.

END



AIA® Document A101® – 2017

Standard Form of Agreement Between Owner and Contractor where the basis of payment is a Stipulated Sum

AGREEMENT made as of the
(In words, indicate day, month and year.)

BETWEEN the Owner:
(Name, legal status, address and other information)

Alief Independent School District
4250 Cook Road
Houston, Texas 77072

and the Contractor:
(Name, legal status, address and other information)

for the following Project:
(Name, location and detailed description)

Alief Independent School District’s CSP 2613
DLR Group Project No. 39-25156-00

The Architect:
(Name, legal status, address and other information)

DLR Group Inc. of Texas
2500 Pacific Avenue, Suite 1600
Dallas, TX 75226

The Owner and Contractor agree as follows.

ADDITIONS AND DELETIONS:

The author of this document has added information needed for its completion. The author may also have revised the text of the original AIA standard form. An *Additions and Deletions Report* that notes added information as well as revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added necessary information and where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

The parties should complete A101®–2017, Exhibit A, Insurance and Bonds, contemporaneously with this Agreement. AIA Document A201®–2017, General Conditions of the Contract for Construction, is adopted in this document by reference. Do not use with other general conditions unless this document is modified.

TABLE OF ARTICLES

- 1 THE CONTRACT DOCUMENTS
 - 2 THE WORK OF THIS CONTRACT
 - 3 DATE OF COMMENCEMENT AND SUBSTANTIAL COMPLETION
 - 4 CONTRACT SUM
 - 5 PAYMENTS
 - 6 DISPUTE RESOLUTION
 - 7 TERMINATION OR SUSPENSION
 - 8 MISCELLANEOUS PROVISIONS
 - 9 ENUMERATION OF CONTRACT DOCUMENTS
- EXHIBIT A INSURANCE AND BONDS

ARTICLE 1 THE CONTRACT DOCUMENTS

§ 1.1 The Contract Documents consist of this Agreement, Conditions of the Contract (General, Supplementary, and other Conditions), all sections of the Project Manual, including Drawings, Specifications, and Addenda issued prior to execution of this Agreement, other documents listed in this Agreement, and written Modifications signed by both parties that are issued after execution of this Agreement, all of which form the Contract, and are as fully a part of the Contract as if attached to this Agreement or repeated herein. As used in the Contract Documents, the terms “AIA Document A201 – 2017”, “General Conditions”, “General Conditions of the Contract for Construction” or “A201-2017” shall refer to the General Conditions document that pertains to the Project, as modified or amended by the Owner for the Project. This Agreement represents the entire and integrated agreement between the Owner and the Contractor and supersedes prior negotiations, representations, or agreements, either written or oral. An enumeration of the Contract Documents and their order of precedence, other than a Modification, appear in Article 9.

§ 1.2 The Board of Trustees, by majority vote, is the only representative of the Owner, an independent school district, having the power to enter into or amend a contract, to approve and execute a Change Order valued at or above \$50,000 or Construction Change Directive that would increase the Contract Sum more than \$50,000, or to agree to an extension to the date of Substantial or Final Completion.

§ 1.3 The Board designates the authorized representatives identified in Paragraph 8.3 to act on its behalf in other respects.

ARTICLE 2 THE WORK OF THIS CONTRACT

The Contractor shall fully execute the Work described in the Contract Documents, except as specifically indicated in the Contract Documents to be the responsibility of others.

ARTICLE 3 DATE OF COMMENCEMENT AND SUBSTANTIAL COMPLETION

§ 3.1 The date of commencement of the Work shall be:

(Check one of the following boxes.)

- The date of this Agreement.
- A date set forth in a notice to proceed issued by the Owner.

Established as follows:

(Insert a date or a means to determine the date of commencement of the Work.)

Init.

AIA Document A101 – 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. “The American Institute of Architects,” “American Institute of Architects,” “AIA,” the AIA Logo, and “AIA Contract Documents” are trademarks of The American Institute of Architects. This document was produced at 17:50:54 ET on 03/02/2026 under Order No.3104241897 which expires on 12/31/2026, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com.

User Notes:

(3B9ADA41)

The date of commencement shall be the day that the Contractor receives a Notice to Proceed from the Owner, which may precede the date of execution of this Agreement. If a Building Permit is not available or other approvals are not available for the entire Project, the Contractor must commence work on those portions of the Project that do not require a Building Permit or other approvals on receipt of a Notice to Proceed. Work at the Project site shall not begin until Owner has received all required payment and performance bonds and insurance.

If a date of commencement of the Work is not selected, then the date of commencement shall be the date of this Agreement.

§ 3.2 The Contract Time shall be measured from the date of commencement of the Work.

§ 3.3 Substantial and Final Completion

§ 3.3.1 Subject to adjustments of the Contract Time as provided in the Contract Documents, the Contractor shall achieve Substantial Completion of the entire Work:

(Check one of the following boxes and complete the necessary information.)

Not later than () calendar days from the date of commencement of the Work.

By the following date: **August 1, 2026**

§ 3.3.2 Subject to adjustments of the Contract Time as provided in the Contract Documents, if portions of the Work are to be completed prior to Substantial Completion of the entire Work, the Contractor shall achieve Substantial Completion of such portions by the following dates:

Portion of Work	Substantial Completion Date
-----------------	-----------------------------

§ 3.3.3 If the Contractor fails to achieve Substantial Completion or Final Completion as provided in this Section 3.3, liquidated damages, if any, shall be assessed as set forth in Section 4.5.

§ 3.3.4 Subject to adjustments of the Contract Time as provided in the Contract Documents, Final Completion shall be completed no later than September 2nd, 2026.

ARTICLE 4 CONTRACT SUM

§ 4.1 The Owner shall pay the Contractor the Contract Sum in current funds for the Contractor's performance of the Contract. The Contract Sum shall be One Million One Hundred and Nine Thousand Dollars and no/100 (\$ 1,109,000.00), subject to additions and deductions as provided in the Contract Documents.

§ 4.2 Alternates

§ 4.2.1 Alternates, if any, included in the Contract Sum:

Item	Price
None	

§ 4.2.2 Subject to the conditions noted below, the following alternates may be accepted by the Owner following execution of this Agreement. Upon acceptance, the Owner shall issue a Modification to this Agreement.

(Insert below each alternate and the conditions that must be met for the Owner to accept the alternate.)

Item	Price	Conditions for Acceptance
------	-------	---------------------------

§ 4.3 Allowances, if any, included in the Contract Sum:

(Identify each allowance.)

Item	Price
Owner Betterment Allowance	\$250.000

§ 4.3.1 The Contract Sum contains an Owner’s Contingency / Owner Betterment Allowance. This contingency is for the sole use of the Owner to be used for changes in the scope of the Work and for the betterment of the Project. Owner’s authorized representative may approve any expenditure from Owner’s Contingency without further Board approval. If the Owner’s Contingency is not expended or not fully expended, then any unused portion shall belong to the Owner and shall be credited to the Owner in calculating final payment.

§ 4.4 Unit prices, if any:
(Identify the item and state the unit price and quantity limitations, if any, to which the unit price will be applicable.)

Item	Units and Limitations	Price per Unit (\$0.00)
None		

§ 4.5 Liquidated damages.
(Paragraph Deleted)

§ 4.5.1 The Work to be performed under this Agreement shall be substantially completed by the date set forth in the Agreement, or by such dates thereafter as may be established in any written extensions granted under Article 8 of the General Conditions. The parties hereto agree that time is of the essence of this Contract and in all phases of the Work, and that actual and direct damages would be suffered by the Owner if the Contractor does not substantially or finally complete all Work called for in the Contract Document by the specified dates. Such actual and direct damages are, and will continue to be, impracticable and extremely difficult to determine. Execution of this Agreement under these specifications shall constitute the agreement by Owner and Contractor that the amounts stated herein are the minimum value of the costs and actual and direct damages caused by failure of Contractor to complete the Work within the allotted or agreed extended times of Substantial or Final Completion, that such sums are liquidated direct damages and as all not be constructed to be as a penalty, and that such sums may be deducted from payments due Contractor if such delay occurs. It is therefore expressly agreed, as a part of the consideration inducing the Owner to execute this Contract, that the Owner may deduct from any payment(s) due to the Contractor a sum equal to One Thousand Dollars (\$1,000.00) for each and every Calendar Day beyond the date set forth in the Agreement for Substantial Completion or Final Completion of the Work included in the Contract Documents. It is expressly understood that said sum per day is agreed upon as a real, justified, and fair estimate of the pecuniary damages which will be sustained by the Owner in the event that the Work is not substantially or finally completed within the agreed time, or with the legally extended time, if any, otherwise provided for herein. Said sum shall be considered as liquidated damages only, and in no sense shall be considered a penalty or forfeiture, said damage being caused by, but not limited to, additional compensation for personnel, attorneys fees, architectural fees, engineering fees, program management fees, inspection fees, storage costs, food service costs, transportation costs, utilities costs, costs of temporary facilities, loss of interest on money, and other miscellaneous increased costs, all of which are difficult of exact ascertainment. Failure to complete the Work within the designated or agreed extended dates of Substantial or Final Completion, shall be construed as a breach of this Agreement.

§ 4.5.2 Such damages shall be in addition to, and not in lieu of, any other rights or remedies Owner may have against Contractor for failure to timely achieve Final Completion, and damages for failure to achieve Substantial Completion and failure to achieve Final Completion shall run concurrently. If the Work is not finally completed by the time stated in the Agreement, or as extended, no payments for Work completed beyond that time shall be made until the Project reaches Final Completion.

§ 4.6 Other:
(Insert provisions for bonus or other incentives, if any, that might result in a change to the Contract Sum.)

None.

ARTICLE 5 PAYMENTS

§ 5.1 Progress Payments

§ 5.1.1 Based upon Applications for Payment submitted to the Architect by the Contractor and Certificates for Payment issued by the Architect, the Owner shall make progress payments on account of the Contract Sum to the Contractor as provided below and elsewhere in the Contract Documents.

§ 5.1.2 The period covered by each Application for Payment shall be one calendar month ending on the last day of the month.

§ 5.1.3 Refer to AIA A201, as modified by the Owner for the project, for Payments.

(Paragraph Deleted)

§ 5.1.4 Each Application for Payment shall be based on the most recent schedule of values submitted by the Contractor in accordance with the Contract Documents. The schedule of values shall allocate the entire Contract Sum, less any unused Owner's contingency, among the various portions of the Work. The schedule of values shall be prepared in such form, and supported by such data to substantiate its accuracy, as the Architect may require, but shall contain as a minimum, individual line items for each section of the table of contents of the Project Manual separated by material costs and labor costs. Additionally, General Conditions costs shall be separated into individual line items. Each Application for Payment shall also include a list, with backup data, of how each payment shall be spent, including a list detailing which subcontractors and suppliers will be paid out of funds paid by the Owner and the amount of such payments to subcontractors and suppliers. Additionally, beginning with the second application for payment, proof of each payment to Contractor's subcontractors and suppliers for payment within 61-days after payment. The Application for Payment shall be submitted on a schedule of values basis. This schedule of values shall be used as a basis for reviewing the Contractor's Applications for Payment.

§ 5.1.5 Applications for Payment shall show the percentage of completion of each portion of the Work as of the end of the period covered by the Application for Payment.

§ 5.1.6 In accordance with AIA Document A201™–2017, as modified by the Owner for the Project, General Conditions of the Contract for Construction, and subject to other provisions of the Contract Documents, the amount of each progress payment shall be provided using the AIA G702 and G703 format and computed as follows:

§ 5.1.6.1 The amount of each progress payment shall first include:

- .1 That portion of the Contract Sum properly allocable to completed Work;
- .2 That portion of the Contract Sum properly allocable to materials and equipment delivered and suitably stored at the site for subsequent incorporation in the completed construction, or, if approved in advance by the Owner, suitably stored off the site at a location agreed upon in writing; and
- .3 That portion of Construction Change Directives that the Architect determines, in the Architect's professional judgment, to be reasonably justified.

§ 5.1.6.2 The amount of each progress payment shall then be reduced by:

- .1 The aggregate of any amounts previously paid by the Owner;
- .2 The amount, if any, for Work that remains uncorrected and for which the Architect has previously withheld a Certificate for Payment as provided in Article 9 of AIA Document A201–2017, as modified by the Owner for the Project;
- .3 Any amount for which the Contractor does not intend to pay a Subcontractor or material supplier, unless the Work has been performed by others the Contractor intends to pay;
- .4 For Work performed or defects discovered since the last payment application, any amount for which the Architect may withhold payment, or nullify a Certificate of Payment in whole or in part, as provided in Article 9 of AIA Document A201–2017 as modified by the Owner for the Project; and
- .5 Retainage withheld pursuant to Section 5.1.7.

§ 5.1.6.3 If Owner is entitled to deduct liquidated damages, or any other damages or amounts provided in the Contract Documents, including clean-up fees, then Owner shall be entitled to deduct such liquidated damages, amounts and fees at any time.

Init.

§ 5.1.6.4 If Contractor fails or refuses to complete the Work, or has unsettled claims with Owner, any payment to Contractor shall be subject to deduction for such amounts as the Architect and Program Manager, if applicable, shall determine as the cost for completing incomplete Work and the value of unsettled claims.

§ 5.1.6.5 Payments shall be made on account of materials and equipment (a) incorporated in the Work, (b) suitably stored at the Project site, or (c) suitably stored at some off-site location provided the following conditions are met for off-site storage:

- .1 The location must be agreed to, in writing, by the Owner and Surety;
- .2 The location must be a bonded warehouse;
- .3 The surety must agree, in writing, to each request for payment; and
- .4 The Contractor must bear the cost of the Owner's and Architect's expenses related to visiting the off-site storage area.

Payment for materials and/or equipment stored on or off the site shall be conditioned upon submission by the Contractor of bills of sale or such other procedures satisfactory to the Owner to establish the Owner's title to such materials and equipment or otherwise protect the Owner's interest, and shall include the costs of applicable insurance (naming the Owner as additional insured) and transportation to the site for those materials and equipment stored off the site. Under no circumstances will the Owner reimburse the Contractor for down payments, deposits, or other advance payments for materials or **equipment**

§ 5.1.7 Retainage

§ 5.1.7.1 For each progress payment made prior to Final Completion of the Work, the Owner may withhold the following amount, as retainage, from the payment otherwise due:

(Insert a percentage or amount to be withheld as retainage from each Application for Payment. The amount of retainage may be limited by governing law.)

Ten percent (10%)

§ 5.1.7.1.1 The following items are not subject to retainage:

(Insert any items not subject to the withholding of retainage, such as general conditions, insurance, etc.)

None.

§ 5.1.7.2 Reduction or limitation of retainage, if any, shall be as follows:

(If the retainage established in Section 5.1.7.1 is to be modified prior to Substantial Completion of the entire Work, including modifications for Substantial Completion of portions of the Work as provided in Section 3.3.2, insert provisions for such modifications.)

No reduction allowed

§ 5.1.7.3 Except as set forth in this Section 5.1.7.3, upon Final Completion of the Work, the Contractor may submit an Application for Payment that includes the retainage withheld from prior Applications for Payment pursuant to this Section 5.1.7. The Application for Payment submitted at Final Completion shall not include retainage as follows:

(Insert any other conditions for release of retainage upon Final Completion.)

Not Applicable

§ 5.1.8 If Final Completion of the Work is materially delayed through no fault of the Contractor, the Owner shall pay the Contractor any additional amounts payable in accordance with Article 9 of AIA Document A201–2017, as modified by the Owner for the Project.

§ 5.1.9 Except with the Owner's prior written approval or as otherwise provided in in Section 9.3.2 of the AIA Document A201-2017, the Contractor shall not make advance payments to suppliers for materials or equipment which have not been delivered and stored at the site. If the Contractor wishes to bill for materials or equipment

Init.

which cannot be stored on site, the Contractor shall, along with the request for approval, provide evidence of purchase, evidence of delivery in good order without damage, and a certificate of insurance specifically covering the material identified by way of serial numbers, bill of lading, and copy of signature of receipt of materials and photography showing material. The Contractor shall also require, at the Owner's request, proof that the facility at which the materials or equipment is stored is bonded. Security and protection from theft and damage remains on the Contractor as the first line of accountability and financial responsibility. Delays due to issues arising from stored materials shall not be considered as reasonable justification to release the Contractor from meeting the schedule unless the Owner agrees to such delay in writing in advance of any delay.

§ 5.2 Final Payment

§ 5.2.1 Final payment, constituting the entire unpaid balance of the Contract Sum, minus disputed sums, authorized deductions, and liquidated damages, shall be made by the Owner to the Contractor after

- .1 the Contractor has fully performed the Contract except for the Contractor's responsibility to correct nonconforming Work as provided in Article 12 of AIA Document A201–2017, as modified by the Owner for the project, and to satisfy other requirements, if any, which extend beyond final payment;
- .2 the Contractor has provided all documents required by Section 3.5 et seq. and 9.10.2 of AIA Document A201-2017; and
- .3 a final Certificate for Payment has been issued by the Architect.

§ 5.2.2 The Owner's final payment to the Contractor shall be made no later than 45 days after Owner's Board's vote or other required approval pursuant to applicable Owner policy. Undisputed amounts unpaid after the date on which payment is due shall bear interest pursuant to Texas Government Code Section 2251.025.

§ 5.3 Interest

Undisputed payments due and unpaid under the Contract shall bear interest at the rate
(Paragraph Deleted)

established by Texas Government Code Chapter 2251.

ARTICLE 6 DISPUTE RESOLUTION

§ 6.1 Initial Decision Maker

The Architect will serve as the Initial Decision Maker pursuant to Article 15 of AIA Document A201–2017, as modified by the Owner for the Project, unless the parties appoint below another individual, not a party to this Agreement, to serve as the Initial Decision Maker.

(Paragraph Deleted)

§ 6.2 Binding Dispute Resolution

For any Claim or dispute between the parties, the method of binding dispute resolution shall be as follows:
(Check the appropriate box.)

(Paragraph Deleted)

[X] Litigation in a court of competent jurisdiction

(Paragraph Deleted)

If the Owner and Contractor do not select a method of binding dispute resolution, or do not subsequently agree in writing to a binding dispute resolution method other than litigation, Claims will be resolved by litigation in a court of competent jurisdiction.

ARTICLE 7 TERMINATION OR SUSPENSION

§ 7.1 The Contract may be terminated by the Owner or the Contractor as provided in Article 14 of AIA Document A201–2017, as amended by the Owner for the Project.

Init.

AIA Document A101 – 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The American Institute of Architects. This document was produced at 17:50:54 ET on 03/02/2026 under Order No.3104241897 which expires on 12/31/2026, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com.

User Notes:

(3B9ADA41)

§ 7.1.1 If the Contract is terminated for the Owner's convenience in accordance with Article 14 of AIA Document A201–2017, as amended by the Owner for the Project, then the Owner shall pay the Contractor a termination fee as follows:

(Insert the amount of, or method for determining, the fee, if any, payable to the Contractor following a termination for the Owner's convenience.)

As described in AIA Document A201-2017, as amended by the Owner for the Project.

§ 7.2 The Work may be suspended by the Owner as provided in Article 14 of AIA Document A201–2017, as amended by the Owner for the Project.

ARTICLE 8 MISCELLANEOUS PROVISIONS

§ 8.1 Where reference is made in this Agreement to a provision of AIA Document A201–2017 or another Contract Document, the reference refers to that provision as amended or supplemented by other provisions of the Contract Documents.

§ 8.2 The Owner's Designated representative:

(Name, address, email address, and other information)

The Owner's Board of Trustees, by majority vote at a duly noticed and lawfully called public meeting, is the only representative of Owner, a Texas independent school district organized under the laws of the State of Texas, having the power to enter into a contract, to execute a change order requiring an increase in an amount of \$50,000 or more, to the Contract Sum, or to agree to an extension to the contractual completion date, unless this authority is lawfully delegated. The Board may designate in writing an authorized representative (or representatives), as appropriate, to act on its behalf during the course of construction. Such authorized representative shall have authority to act on behalf of the Owner concerning decisions that do not require a majority vote of the Board of Trustees and shall have the authority to bind the Owner only to the extent expressly authorized or delegated by the Board of Trustees. The authorized representative shall have no implied authority. Such authorized representative shall also bring recommendations to the Board of Trustees on any matter requiring Board approval. In the event that changes in the scope of the Work are required before the Board's next regularly scheduled meeting or in order to facilitate and expedite the timely completion of the Work, the Board's authorized representative shall have authority to approve construction changes that do not exceed \$50,000.00 in increased costs. Any such change shall be confirmed in writing between the Contractor and the Board's authorized representative and notice of such approved changes shall be given to the Board at its next regularly scheduled meeting. The Board shall act as soon as reasonably possible to avoid unnecessary delays in the construction completion date. Except as expressly authorized by the Owner or the Contract Documents, the Architect does not have the authority to bind the Owner. The term "Owner" means the Owner or the Owner's authorized representative.

§ 8.3 The Owner's authorized representative:

Superintendent of Schools

§ 8.3 The Contractor's representative:

(Name, address, email address, and other information)

§ 8.4 The Contractor's representative shall be changed without ten days' prior notice to the other party.

§ 8.5 Insurance and Bonds

§ 8.5.1 The Contractor shall purchase and maintain insurance as set forth in Exhibit A, Insurance and Bonds, and elsewhere in the Contract Documents.

§ 8.5.2 The Contractor shall provide bonds as set forth in AIA Document A101™–2017 Exhibit A, and elsewhere in the Contract Documents.

§ 8.6 All notices required to be given under the Contract must be in writing. Any notice required or permitted to be given under the Contract shall be deemed delivered, whether or not actually received, three days after it is deposited in the U.S. Mail, when sent by certified mail, return receipt requested, postage prepaid, and correctly addressed to the party at the address provided in this Agreement. Notice given in any other manner shall be deemed delivered when actually received. Either party may change its address for notice by giving notice of the change of address in accordance with this provision. The Architect must be copied on notices sent to the Owner.

§ 8.7 Other provisions:

§ 8.7.1 The subject of this Contract is a public school facility which is governed by School Facilities Standards promulgated by the State Board of Education and said project must be constructed in compliance with these Standards. Upon request, Owner, its authorized agent, its Architect, and/or its Engineer shall make available information related to the School Facilities Standards necessary for compliance with said Standards.

§ 8.7.2 The Owner is an organization exempt from Texas taxes. Owner shall not be responsible for sales, consumer, use, and similar taxes on labor, materials, equipment, systems, and other items purchased for the project which Owner would ordinarily be exempt.

§ 8.7.3 All provisions in the Contract Documents that mandate arbitration are expressly deleted and rendered null and void.

§ 8.7.4 Subcontracts, purchase orders and rental agreements entered into by the Contractor shall contain provisions permitting assignment to the Owner upon default by Contractor under the Contract Documents. If the Owner accepts such assignment, the Owner shall be responsible for the payment of amounts which would have been reimbursable to Contractor under this Agreement and for which payment has not already been made to the Contractor. Contractor shall be responsible for the payment of any other amounts payable under the Contract. If the Owner elects not to accept the assignment of any subcontract, purchase order or rental agreement which would have constituted a Cost of the Work had this agreement not been terminated, the Contractor shall terminate such subcontract, purchase order or rental agreement.

§ 8.7.5 Unless the context of this Agreement otherwise clearly requires, references to the plural include the singular, the term “including” is not limiting and the terms “hereof,” “herein,” “hereunder” and similar terms in the Contract Documents refer to the Contract Documents as a whole and not to any particular provision thereof, unless stated otherwise. Additionally, the parties hereto acknowledge that they have carefully reviewed this Agreement and have been advised by counsel of their choosing with respect thereto, and that they understand its contents and agree that this Agreement shall not be construed more strongly against any part hereto regardless of who is responsible for its preparation.

§ 8.7.6 In the event of any suit or action arising out of or in connection with any of the Contract Documents, the prevailing party in such proceedings shall be entitled to recover reasonable attorney fees and court costs.

§ 8.7.7 Any provision in the Contract Documents to the contrary notwithstanding, if any of the facilities to be constructed or modified under this Agreement or the Contract require the issuance of a Certificate of Occupancy or other regulatory approval, then Substantial Completion of any such facilities shall not be deemed to have been attained for those facilities prior to the date on which an unconditional Certificate of Occupancy or other regulatory approval is obtained.

§ 8.7.8 If the building will be used or occupied by the Owner or members of the public, the Contractor shall be responsible for maintaining safe routes of travel from sidewalks and parking areas to the building, and shall reroute access as necessary to maintain safe access during construction at no additional cost beyond the agreed contract amount.

§ 8.7.9 By signing this Agreement or providing or causing to be provided a certificate of coverage, the Contractor is certifying to the Owner that all employees of the Contractor who will provide services on the Project will be covered by workers’ compensation coverage for the duration of the Project. Contractor is also representing that it will require all subcontractors to provide workers’ compensation coverage on all employees who will provide services on the Project for the duration of the Project and to provide written certifications of such coverage to the Contractor.

The Contractor will provide the certifications to Owner. Providing false or misleading information may subject the Contractor to administrative penalties, criminal penalties, civil penalties, or other civil actions. The Contractor's failure to comply with any of these provisions is a breach of contract by the Contractor which entitles the Owner to declare the contract void if the Contractor does not remedy the breach within ten days after receipt of notice of breach from the Owner.

§ 8.7.10 The Contractor shall, as a condition precedent to allowing any subcontractor to proceed with any work on the Project, either require that the subcontractor provide proof of the existence of workers' compensation coverage for its employees, or, at the Contractor's sole discretion, provide for coverage of the subcontractor's employees under the Contractor's workers' compensation insurance coverage. The Contractor shall maintain records of all required certificates of insurance provided by the subcontractors, and shall forward copies to the Owner and the Architect.

§ 8.7.11 Warranty. The Contractor shall be responsible for the coordination of warranty work, if any during the first year after Substantial Completion of the Entire Work.

§ 8.7.12 No provision of this Agreement shall waive any immunity or defense. No provision of this Agreement is a waiver of any immunity or a consent to suit.

§ 8.7.13 The Owner's competitive procurement solicitation documents/packet and the response of the Contractor to same are incorporated herein by reference as if copied verbatim. The Contractor agrees to comply with all requirements incorporated or included in the competitive procurement solicitation documents/packet by the Owner

§ 8.7.14 The Contractor shall record the progress of the Project. On a monthly basis, or as otherwise agreed to by the Owner, the Contractor shall submit written progress reports to the Owner and Architect, showing percentages of completion and other information required by the Owner. The Contractor shall also keep, and make available to the Owner and Architect, a daily log containing a record for each day of weather, portions of the Work in progress and accomplished, Subcontractors working on the site, number of workers on site, identification of equipment on site, problems that might affect progress of the work, accidents, injuries, and other information required by the Owner. The log shall be available to the Owner and Architect at any time during work hours and shall be presented for discussion at the project progress meetings.

§ 8.7.15 If (a) Contractor is not a sole proprietorship; (b) Contractor has ten (10) or more full-time employees; and (c) this Agreement has a value of \$100,000 or more, the following certification shall apply; otherwise, this certification is not required. Pursuant to Chapter 2270 of the Texas Government Code, the Contractor hereby certifies and verifies that neither the Contractor, nor any affiliate, subsidiary, or parent company of the Contractor, if any (the "Contractor Companies"), boycotts Israel, and the Architect agrees that the Contractor and Contractor Companies will not boycott Israel during the term of this Agreement. For purposes of this Agreement, the term "boycott" shall mean and include refusing to deal with, terminating business activities with, or otherwise taking any action that is intended to penalize, inflict economic harm on, or limit commercial relations with Israel, or with a person or entity doing business in Israel or in an Israeli-controlled territory, but does not include an action made for ordinary business purposes.

§ 8.7.16 Contractor verifies and affirms that it is not a foreign terrorist organization as identified on the list prepared and maintained by the Texas Comptroller of Public Accounts. If Contractor misrepresents its inclusion on the list, then such omission or misrepresentation shall void this Agreement.

§ 8.7.17 *If Contractor is not a governmental body and (a) this Agreement has a stated expenditure of at least \$1 million in public funds for the purchase of goods or services by Owner; or (b) this Agreement results in the expenditure of at least \$1 million in public funds for the purchase of goods or services by Owner in a fiscal year of Owner, the following certification shall apply; otherwise, this certification is not required. As required by Tex. Gov't Code § 552.374(b), the following statement is included in the RFP and the Agreement (unless the Agreement is (1) related to the purchase or underwriting of a public security; (2) is or may be used as collateral on a loan; or (3) proceeds from which are used to pay debt service of a public security of loan): "The requirements of Subchapter J, Chapter 552, Government Code, may apply to this RFP and Agreement and the Contractor agrees that the Contract can be terminated if the Contractor knowingly or intentionally fails to comply with a requirement of that subchapter." Pursuant to Subchapter J, Chapter 552, Texas Government Code, the Contractor hereby certifies and*

Init.

agrees to (1) preserve all contracting information related to this Agreement as provided by the records retention requirements applicable to Owner for the duration of the Agreement; (2) promptly provide to Owner any contracting information related to the Agreement that is in the custody or possession of the Contractor on request of Owner; and (3) on completion of the Agreement, either (a) provide at no cost to Owner all contracting information related to the Agreement that is in the custody or possession of Contractor, or (b) preserve the contracting information related to the Agreement as provided by the records retention requirements applicable to Owner.

§ 8.7.18 If (a) Contractor is not a sole proprietorship; (b) Contractor has ten (10) or more full-time employees; and (c) this Agreement has a value of \$100,000 or more that is to be paid wholly or partly from public funds, the following certification shall apply; otherwise, this certification is not required. Pursuant to Tex. Gov't Code Ch. 2274 of SB 13 (87th session), Contractor hereby certifies and verifies that Contractor, or any wholly owned subsidiary, majority-owned subsidiary, parent company, or affiliate of these entities or business associations, if any, does not boycott energy companies and will not boycott energy companies during the term of the Contract. For purposes of this Agreement, the term "company" shall mean an organization, association, corporation, partnership, joint venture, limited partnership, limited liability partnership, or limited liability company, that exists to make a profit. The term "boycott energy company" shall mean "without an ordinary business purpose, refusing to deal with, terminating business activities with, or otherwise taking any action intended to penalize, inflict economic harm on, or limit commercial relations with a company because the company (a) engages in the exploration, production, utilization, transportation, sale, or manufacturing of fossil fuel-based energy and does not commit or pledge to meet environmental standards beyond applicable federal and state law, or (b) does business with a company described by paragraph (a)." See Tex. Gov't Code § 809.001(1).

§ 8.7.19 If (a) Contractor is not a sole proprietorship; (b) Contractor has at least ten (10) full-time employees; (c) this Agreement has a value of at least \$100,000 that is paid wholly or partly from public funds; (d) the Contract is not excepted under Tex. Gov't Code § 2274.003 of SB 19 (87th leg.); and (e) Owner has determined that Contractor is not a sole-source provider or Owner has not received any bids from a company that is able to provide this written verification, the following certification shall apply; otherwise, this certification is not required. Pursuant to Tex. Gov't Code Ch. 2274 of SB 19 (87th session), Contractor hereby certifies and verifies that Contractor, or association, corporation, partnership, joint venture, limited partnership, limited liability partnership, or limited liability company, including a wholly owned subsidiary, majority-owned subsidiary parent company, or affiliate of these entities or associations, that exists to make a profit, does not have a practice, policy, guidance, or directive that discriminates against a firearm entity or firearm trade association and will not discriminate during the term of this contract against a firearm entity or firearm trade association. For purposes of this Agreement, "discriminate against a firearm entity or firearm trade association" shall mean, with respect to the entity or association, to: "(1) refuse to engage in the trade of any goods or services with the entity or association based solely on its status as a firearm entity or firearm trade association; (2) refrain from continuing an existing business relationship with the entity or association based solely on its status as a firearm entity or firearm trade association; or (3) terminate an existing business relationship with the entity or association based solely on its status as a firearm entity or firearm trade association. See Tex. Gov't Code § 2274.001(3) of SB 19. "Discrimination against a firearm entity or firearm trade association" does not include: "(1) the established policies of a merchant, retail seller, or platform that restrict or prohibit the listing or selling of ammunition, firearms, or firearm accessories; and (2) a company's refusal to engage in the trade of any goods or services, decision to refrain from continuing an existing business relationship, or decision to terminate an existing business relationship to comply with federal, state, or local law, policy, or regulations or a directive by a regulatory agency, or for any traditional business reason that is specific to the customer or potential customer and not based solely on an entity's or association's status as a firearm entity or firearm trade association." See Tex. Gov't Code § 2274.001(3) of SB 19.

§ 8.7.20 Owner is prohibited from entering into a contract or other agreement relating to critical infrastructure that would grant to Contractor direct or remote access to or control of critical infrastructure in this state, excluding access specifically allowed by Owner for product warranty and support purposes. Contractor certifies that neither it nor its parent company nor any affiliate of Contractor or its parent company, is (1) owned by or the majority of stock or other ownership interest of the company is held or controlled by individuals who are citizens of China, Iran, North Korea, Russia, or a designated country; (2) a company or other entity, including governmental entity, that is owned or controlled by citizens of or is directly controlled by the government of China, Iran, North Korea, Russia, or a designated country; or (3) headquartered in China, Iran, North Korea, Russia, or a designated country. For purposes of this Contract, "critical infrastructure" means "a communication infrastructure system, cybersecurity system, electric grid, hazardous waste treatment system, or water treatment facility." See Tex. Gov't Code § 2274.0101(2)

of SB 1226 (87th leg.). Contractor verifies and certifies that Contractor will not grant direct or remote access to or control of critical infrastructure, except for product warranty and support purposes, to prohibited individuals, companies, or entities, including governmental entities, owned, controlled, or headquartered in China, Iran, North Korea, Russia, or a designated country, as determined by the Governor.

§ 8.7.21 Program Manager shall have, and is hereby granted by Owner, full and complete power, authority, and discretion to act for, and in the name, place, and stead of, Owner in carrying out and discharging the responsibilities and obligations of Program Manager under the Agreement between the Owner and Program Manager; provided, however, that Program Manager shall have no right or authority, express or implied, to commit or otherwise obligate Owner in any manner whatsoever except to the extent specifically provided in the Agreement between the Owner and the Program Manager or specifically authorized in writing by Owner. In no event shall Program Manager be authorized to execute any documents, agreements, or other instruments on behalf of Owner without written approval by Owner. In no event shall Program Manager have the authority to modify completion dates of the Project Schedule without written approval by Owner. Program Manager shall have the authority to modify interim milestones dates not affecting the completion dates specified in the Agreements between the parties. In no event shall Program Manager have the authority to modify contract value of the Project without written approval by Owner. Program Manager shall have the authority to modify budgets, contingencies, allowances and similar accounting tasks not affecting the contract value specified in the Agreements between the parties. In no event shall Program Manager have the authority to relax or to bind the Owner to codes and standards imposed by the Authorities Having Jurisdiction, unless authorized in writing by the Owner.

§ 8.7.22 The Contractor shall utilize online project management software as required by the Owner.

§ 8.8 Governing Law and Venue

§ 8.8.1 Section 13.1 of the General Conditions document pertaining to the Project, as modified by the Owner, shall apply to the Agreement, the Contract, and the Contract documents in all respects. No provision of this Agreement is a waiver of any immunity, defense, or a consent to suit.

§ 8.8.2 Venue

To the maximum extent permitted by applicable law, the parties expressly agree that the exclusive venue and place of trial for any action brought under or in connection with or in any way related to the Work, the Project, the Agreement, the Contract, or any of the Contract Documents shall be in the state district courts of Harris County, Texas, and the parties hereby waive any and all objections to the agreed-upon venue as stated herein. The Contract, including but not limited to the Agreement and all other Contract Documents, is performable entirely in Harris County, Texas.

§ 8.9 Severability

If any provision or part of the Contract Documents is held to be illegal, invalid, or unenforceable under any present or future law or regulation, such provision shall be fully severable and the Contract Documents shall be construed and enforced as if such illegal, invalid or unenforceable provision had never comprised a part of the Contract Documents. The remaining provisions of the Contract Documents shall remain in full force and effect and shall not be affected by the illegal, invalid, or unenforceable provision or by its severance.

§ 8.10 Information and Services Required of the Owner

§ 8.10.1 Pursuant to the requirements of the Texas Business and Commerce Code section 56.054(e)(3), the Owner represents that funds are available and have been authorized for the full contract amount of the work.

ARTICLE 9 ENUMERATION OF CONTRACT DOCUMENTS

§ 9.1 This Agreement is comprised of the following documents; in the event of any inconsistency or conflict between or among the documents that comprise this Agreement, the order of precedence shall be:

- .1** AIA Document A101TM-2017, Standard Form of Agreement Between Owner and Contractor, as modified by Owner for the Project
- .2** Exhibit A, Insurance and Bonds
- .3** AIA Document A201TM-2017, General Conditions of the Contract for Construction, as
modified by the Owner for the project

.5 Drawings

Number	Title	Date
See attached Exhibit "A"	Cover Sheet – Alief MS	May 6, 2025
See attached Exhibit "B"	Cover Sheet – Boone ES	October 31, 2025
See attached Exhibit "C"	Cover Sheet – Elsik HS	October 31, 2025
See attached Exhibit "D"	Cover Sheet – Heflin ES	May 6, 2025
See attached Exhibit "E"	Cover Sheet – Rees ES	October 31, 2025
See attached Exhibit "F"	Cover Sheet – Smith ES	May 6, 2025

.6 Specifications

Section	Title	Date	Pages
See attached Exhibit "G"	Table of Contents – Package 1	February 11, 2026	3
See attached Exhibit "H"	Table of Contents – Package 2	February 11, 2026	4

.7 Addenda, if any:

Number	Date	Pages
Addendum 1 Phase 1 (Alief MS)	June 12, 2025	14
Addendum 1 Phase 1 (Heflin ES)	June 12, 2025	13
Addendum 1 Phase 1 (Smith ES)	June 12, 2025	24
Addendum 2 Phase 1 (Alief MS)	August 5, 2025	8
Addendum 2 Phase 1 (Heflin ES)	August 5, 2025	9
Addendum 2 Phase 1 (Smith ES)	August 5, 2025	11
Addendum 3 Phase 1 (Alief MS, Heflin ES, Smith ES)	May 6, 2025	18
Addendum 4 Phase 1 (Alief MS)	May 19, 2025	44
Addendum 4 Phase 1 (Heflin ES)	May 19, 2025	9
Addendum 4 Phase 1 (Smith ES)	May 19, 2025	9
Addendum 5 Phase 1 (Alief MS)	October 31, 2025	48
Addendum 5 Phase 1 (Heflin ES)	October 31, 2025	27
Addendum 5 Phase 1 (Smith ES)	October 31, 2025	27
Addendum 1 Phase 2 (Boone ES)	December 8, 2025	2
Addendum 1 Phase 2 (Elsik HS)	January 13, 2026	5
Addendum 2 Phase 2 (Boone ES)	January 13, 2026	9
Addendum 3 Phase 2 (Boone ES)	February 25, 2026	6
Addendum 6 Phase 2 (Heflin ES)	February 25, 2026	2

Portions of Addenda relating to bidding or competitive purchasing requirements are not part of the Contract Documents unless the bidding or competitive purchasing requirements are also enumerated in this Article 9.

.8

(Paragraphs Deleted)

(Table Deleted)

(Paragraph Deleted)

(Table Deleted)

Other documents, if any, listed below:

(List here any additional documents that are intended to form part of the Contract Documents. AIA Document A201™-2017 provides that the advertisement or invitation to bid, Instructions to Bidders, sample forms, the Contractor's bid or proposal, portions of Addenda relating to bidding or proposal requirements, and other information furnished by the Owner in anticipation of receiving bids or proposals, are not part of the Contract Documents unless enumerated in this Agreement. Any such documents should be listed here only if intended to be part of the Contract Documents.)

- .1 Owner's competitive procurement solicitation documents, including Owner's required certifications/Vendor Packet.
- .2 The Project Manual for the Project, including all sections to same, whether issued or created prior to or after the execution of this Agreement.
- .3 Statutory Payment and Performance Bonds.
- .4 Certificates of Insurance required of the Contractor.
- .5 All documents listed or described in Section 1.1.1 of AIA Document A201-2017, as amended by the Owner.
- .6 Scale/Schedule of Prevailing Wages (attached as Exhibit A to the AIA Document A201-2017, General Conditions of the Contract for Construction, as modified by the Owner for the Project) and incorporated herein as if fully set forth.
- .7 Any modifications to this Agreement or to the Contract or any Contract Documents approved by the Parties.
- .8 Any documents stated in this Agreement as being a part of or incorporated into this Agreement or the Contract
- .9 Portion(s) of Contractor's responses and proposals to Owner's competitive procurement solicitation documents that were accepted by Owner.

This Agreement entered into as of the day and year first written above.

OWNER *(Signature)*

Dr. Anthony Mays
Superintendent of Schools

(Printed name and title)

(Date)

CONTRACTOR *(Signature)*

(Printed name and title)

(Date)

SECTION 000110 – TABLE OF CONTENTS

DIVISION 00 — PROCUREMENT AND CONTRACTING REQUIREMENTS

000107	SEALS PAGE
000110	TABLE OF CONTENTS

DIVISION 01 — GENERAL REQUIREMENTS

011000	SUMMARY - PACKAGE I
012500	SUBSTITUTION PROCEDURES
012500A	POST-BID REQUEST FOR SUBSTITUTIONS FORM
012600	CONTRACT MODIFICATION PROCEDURES
012900	PAYMENT PROCEDURES
012901	STATUTORY LIEN WAIVER FORMS LONG
012901A	FORM 1 CONDITIONAL WAIVER FOR PROGRESS PAYMENTS
012901B	FORM 2 UNCONDITIONAL WAIVER FOR PROGRESS PAYMENTS
012901C	FORM 3 CONDITIONAL WAIVER FOR FINAL PAYMENT
012901D	FORM 4 UNCONDITIONAL WAIVER FOR FINAL PAYMENT
013100	PROJECT MANAGEMENT AND COORDINATION
013200	CONSTRUCTION PROGRESS DOCUMENTATION
013300	SUBMITTAL PROCEDURES
013516	ALTERATION PROJECT PROCEDURES
014000	QUALITY REQUIREMENTS
014200	REFERENCES
015000	TEMPORARY FACILITIES AND CONTROLS
016000	PRODUCT REQUIREMENTS
017300	EXECUTION
017700	CLOSEOUT PROCEDURES
017700A	NONASBESTOS LEAD AND PCB USE AFFIDAVIT FORM
017823	OPERATION AND MAINTENANCE DATA
017839	PROJECT RECORD DOCUMENTS
019113	GENERAL COMMISSIONING REQUIREMENTS

DIVISION 02 — EXISTING CONDITIONS

024119	SELECTIVE DEMOLITION
--------	----------------------

DIVISION 04 — MASONRY

042200	CONCRETE UNIT MASONRY
--------	-----------------------

DIVISION 06 — WOOD, PLASTICS, AND COMPOSITES

061000	ROUGH CARPENTRY
--------	-----------------

DIVISION 07 — THERMAL AND MOISTURE PROTECTION

078413	PENETRATION FIRESTOPPING
078443	JOINT FIRESTOPPING
079200	JOINT SEALANTS

079219 ACOUSTICAL JOINT SEALANTS

DIVISION 08 — OPENINGS

081213 HOLLOW METAL FRAMES
081416 FLUSH WOOD DOORS
083113 ACCESS DOORS AND FRAMES
087100.11 DOOR HARDWARE - ALIEF MIDDLE SCHOOL
087100.13 DOOR HARDWARE - BOONE ELEMENTARY SCHOOL
087100.15 DOOR HARDWARE - REES ELEMENTARY SCHOOL
087100.17 DOOR HARDWARE - SMITH ELEMENTARY SCHOOL

DIVISION 09 — FINISHES

092216 NON-STRUCTURAL METAL FRAMING
092900 GYPSUM BOARD
093013 CERAMIC TILING
095113 ACOUSTICAL PANEL CEILINGS
096513 RESILIENT BASE AND ACCESSORIES
099124 INTERIOR PAINTING

DIVISION 10 — SPECIALTIES

101423.16 ROOM-IDENTIFICATION PANEL SIGNAGE
102113.19 PLASTIC TOILET COMPARTMENTS
102800 TOILET, BATH, AND LAUNDRY ACCESSORIES

DIVISION 22 — PLUMBING

220200 BASIC MATERIALS AND METHODS FOR PLUMBING
220201 COORDINATION DRAWINGS
220300 PLUMBING DEMOLITION FOR REMODELING
220513 COMMON MOTOR REQUIREMENTS FOR PLUMBING EQUIPMENT
220516 EXPANSION FITTINGS AND LOOPS FOR PLUMBING PIPING
220529 HANGERS AND SUPPORT FOR PLUMBING PIPING AND EQUIPMENT
220548 VIBRATION AND SEISMIC CONTROLS FOR PLUMBING PIPING
220553 IDENTIFICATION FOR PLUMBING PIPING AND EQUIPMENT
220716 PLUMBING EQUIPMENT INSULATION
220719 PLUMBING PIPING INSULATION
220800 COMMISSIONING OF PLUMBING SYSTEMS
221000 PLUMBING PIPING - ALIEF MIDDLE SCHOOL
221000 PLUMBING PIPING - BOONE ELEMENTARY SCHOOL
221000 PLUMBING PIPING - REES ELEMENTARY SCHOOL
221000 PLUMBING PIPING - SMITH ELEMENTARY SCHOOL
221119 PLUMBING SPECIALTIES
223000 PLUMBING EQUIPMENT
224000 PLUMBING FIXTURES

DIVISION 23 — HEATING VENTILATING AND AIR CONDITIONING

230200 BASIC MATERIALS AND METHODS FOR HVAC
230201 COORDINATION DRAWINGS

230300	MECHANICAL DEMOLITION FOR REMODELING
230529	HANGERS AND SUPPORTS FOR PIPING AND EQUIPMENT - HVAC
230593	TESTING, ADJUSTING, AND BALANCING
230713	DUCT INSULATION
233113	METAL DUCTWORK
233300	DUCTWORK ACCESSORIES
233713	AIR DISTRIBUTION DEVICES

DIVISION 26 — ELECTRICAL

260200	BASIC MATERIALS AND METHODS FOR ELECTRICAL
260201	COORDINATION DRAWINGS
260313	ELECTRICAL DEMOLITION FOR REMODELING
260519	WIRE, CABLE AND RELATED MATERIALS
260526	GROUNDING
260533	RACEWAYS
260634	LOW VOLTAGE RACEWAY SYSTEM
260800	COMMISSIONING OF ELECTRICAL SYSTEMS
260936	LIGHTING CONTROLS (STAND-ALONE)
262416	PANELBOARDS
262726	WIRING DEVICES
262813	FUSES
262816	SAFETY AND DISCONNECT SWITCHES
262901	MOTORS AND STARTERS
262926	MISCELLANEOUS ELECTRICAL CONTROLS AND WIRING
264313.13	SURGE PROTECTIVE DEVICES (SPD) - STANDARD INTERRUPTING
265119	LIGHTING FIXTURES - LIGHT EMITTING DIODE (LED)

DIVISION 28 — ELECTRONIC SAFETY AND SECURITY

280500	BASIC MATERIALS AND METHODS FOR FIRE ALARM
284600	FIRE ALARM SYSTEM WITH ELECTRONIC AUDIO AND VISUAL DEVICES

END OF SECTION 000110

SECTION 000110 – TABLE OF CONTENTS

DIVISION 00 — PROCUREMENT AND CONTRACTING REQUIREMENTS

000107 SEALS PAGE

DIVISION 01 — GENERAL REQUIREMENTS

011000 SUMMARY - PACKAGE II
012500 SUBSTITUTION PROCEDURES
012500A POST-BID REQUEST FOR SUBSTITUTIONS FORM
012600 CONTRACT MODIFICATION PROCEDURES
012900 PAYMENT PROCEDURES
012901 STATUTORY LIEN WAIVER FORMS LONG
012901A FORM 1 CONDITIONAL WAIVER FOR PROGRESS PAYMENTS
012901B FORM 2 UNCONDITIONAL WAIVER FOR PROGRESS PAYMENTS
012901C FORM 3 CONDITIONAL WAIVER FOR FINAL PAYMENT
012901D FORM 4 UNCONDITIONAL WAIVER FOR FINAL PAYMENT
013100 PROJECT MANAGEMENT AND COORDINATION
013200 CONSTRUCTION PROGRESS DOCUMENTATION
013300 SUBMITTAL PROCEDURES
013516 ALTERATION PROJECT PROCEDURES
014000 QUALITY REQUIREMENTS
014200 REFERENCES
015000 TEMPORARY FACILITIES AND CONTROLS
016000 PRODUCT REQUIREMENTS
017300 EXECUTION
017700 CLOSEOUT PROCEDURES
017700A NONASBESTOS LEAD AND PCB USE AFFIDAVIT FORM
017823 OPERATION AND MAINTENANCE DATA
017839 PROJECT RECORD DOCUMENTS
019113 GENERAL COMMISSIONING REQUIREMENTS

DIVISION 02 — EXISTING CONDITIONS

024119 SELECTIVE DEMOLITION

DIVISION 04 — MASONRY

042200 CONCRETE UNIT MASONRY

DIVISION 06 — WOOD, PLASTICS, AND COMPOSITES

061000 ROUGH CARPENTRY

DIVISION 07 — THERMAL AND MOISTURE PROTECTION

078413 PENETRATION FIRESTOPPING
078443 JOINT FIRESTOPPING
079200 JOINT SEALANTS
079219 ACOUSTICAL JOINT SEALANTS

DIVISION 08 — OPENINGS

081213	HOLLOW METAL FRAMES
081416	FLUSH WOOD DOORS
083113	ACCESS DOORS AND FRAMES
087100.19	DOOR HARDWARE - ELSIK HIGH SCHOOL
087100.21	DOOR HARDWARE - HEFLIN ELEMENTARY SCHOOL

DIVISION 09 — FINISHES

092216	NON-STRUCTURAL METAL FRAMING
092900	GYP SUM BOARD
093013	CERAMIC TILING
096513	RESILIENT BASE AND ACCESSORIES
099124	INTERIOR PAINTING

DIVISION 10 — SPECIALTIES

101423.16	ROOM-IDENTIFICATION PANEL SIGNAGE
102113.19	PLASTIC TOILET COMPARTMENTS
102800	TOILET, BATH, AND LAUNDRY ACCESSORIES

DIVISION 22 — PLUMBING

220200	BASIC MATERIALS AND METHODS FOR PLUMBING
220201	COORDINATION DRAWINGS
220300	PLUMBING DEMOLITION FOR REMODELING
220513	COMMON MOTOR REQUIREMENTS FOR PLUMBING EQUIPMENT
220516	EXPANSION FITTINGS AND LOOPS FOR PLUMBING PIPING
220529	HANGERS AND SUPPORT FOR PLUMBING PIPING AND EQUIPMENT
220548	VIBRATION AND SEISMIC CONTROLS FOR PLUMBING PIPING
220553	IDENTIFICATION FOR PLUMBING PIPING AND EQUIPMENT
220716	PLUMBING EQUIPMENT INSULATION
220719	PLUMBING PIPING INSULATION
220800	COMMISSIONING OF PLUMBING SYSTEMS
221000	PLUMBING PIPING- ELSIK HS
221000	PLUMBING PIPING-HELFIN ES
221119	PLUMBING SPECIALTIES
223000	PLUMBING EQUIPMENT
224000	PLUMBING FIXTURES

DIVISION 23 — HEATING VENTILATING AND AIR CONDITIONING

230200	BASIC MATERIALS AND METHODS FOR HVAC
230201	COORDINATION DRAWINGS
230300	MECHANICAL DEMOLITION FOR REMODELING
230529	HANGERS AND SUPPORTS FOR PIPING AND EQUIPMENT - HVAC
230593	TESTING, ADJUSTING, AND BALANCING
230713	DUCT INSULATION
233113	METAL DUCTWORK
233300	DUCTWORK ACCESSORIES
233713	AIR DISTRIBUTION DEVICES

DIVISION 26 — ELECTRICAL

260200	BASIC MATERIALS AND METHODS FOR ELECTRICAL
260201	COORDINATION DRAWINGS
260313	ELECTRICAL DEMOLITION FOR REMODELING
260519	WIRE, CABLE AND RELATED MATERIALS
260526	GROUNDING
260533	RACEWAYS
260634	LOW VOLTAGE RACEWAY SYSTEM
260800	COMMISSIONING OF ELECTRICAL SYSTEMS
260936	LIGHTING CONTROLS (STAND-ALONE)
262416	PANELBOARDS
262726	WIRING DEVICES
262813	FUSES
262816	SAFETY AND DISCONNECT SWITCHES
262901	MOTORS AND STARTERS
262926	MISCELLANEOUS ELECTRICAL CONTROLS AND WIRING
264313.13	SURGE PROTECTIVE DEVICES (SPD) - STANDARD INTERRUPTING
265119	LIGHTING FIXTURES - LIGHT EMITTING DIODE (LED)

DIVISION 28 — ELECTRONIC SAFETY AND SECURITY

280500	BASIC MATERIALS AND METHODS FOR FIRE ALARM
284600	FIRE ALARM SYSTEM WITH ELECTRONIC AUDIO AND VISUAL DEVICES

END OF SECTION 000110

This page intentionally left blank.

DLR Group inc. of Texas
a Texas corporation
2500 Pacific Avenue, Suite 1600
Dallas, Texas 75226

ALIEF ISD
BOONE ES – RESTROOM RENOVATIONS
HOUSTON, TX

DLR GROUP PROJECT NO. 39-25156-00

<TYPE OF CONTRACT>
02-25-26

NOTICE TO BIDDERS/CONTRACTOR: Amend the Project Manuals and Drawings to the above referenced project as follows:

PROJECT MANUAL

ITEM NO. 1. NA

DRAWINGS

ITEM NO. 1. SHEET A2.3 ENLARGED FLOOR PLANS AND ELEVATIONS

A. Drawing 4A/A2.3, adjust wall tile as shown.

ITEM NO. 2. SHEET A2.5 – ENLARGED FLOOR PLANS AND ELEVATIONS

A. Drawing 4A/A2.5, adjust wall tile as shown.

B. Drawing 4b/a2.5, adjust wall tile as shown.

ITEM NO. 3. SHEET A2.6 – ENLARGED FLOOR PLANS AND ELEVATIONS

A. Drawing 4C/A2.6, adjust wall tile as shown.


ITEM NO. 4. SHEET A2.7 ENLARGED FLOOR PLANS AND ELEVATIONS

A. Drawing 1A/A2.7, adjust wall types as shown and noted.


ITEM NO. 5. SHEET A8.2 DOOR & FRAME TYPES & SCHEDULE

A. Adjust partition types as shown and noted.


End of Addenda 03




2A ENLARGED FLOOR PLAN - BOYS 218 / GIRLS 222
A2.3 SCALE: 1/4" = 1'-0"




2C ENLARGED REFLECTED CEILING PLAN - BOYS 218 / GIRLS 222
A2.3 SCALE: 1/4" = 1'-0"




4A PLAN NORTHEAST - BOYS 218
A2.3 SCALE: 1/4" = 1'-0"




4B PLAN WEST ELEVATION - BOYS 218
A2.3 SCALE: 1/4" = 1'-0"




4C ELEVATION AT DRINKING FOUNTAIN
A2.3 SCALE: 1/4" = 1'-0"



5A 222 - GIRLS - NORTH
A2.3 SCALE: 1/4" = 1'-0"



5B 222 GIRLS - SOUTHEAST
A2.3 SCALE: 1/4" = 1'-0"



5D 222 - GIRLS - WEST
A2.3 SCALE: 1/4" = 1'-0"

TOILET ACCESSORIES ABBREVIATIONS

ABBREV	DESCRIPTION
ACC	ADA ACCESSIBLE
BCS	BABY CHANGING STATION
EWG	ELECTRIC WATER COOLER
FSS	FOLDING SHOWER SEAT
GB-1	GRAB BAR (BACK WALL)
GB-2	GRAB BAR (SIDE WALL)
GB-3	GRAB BAR (VERTICAL)
GB-4	GRAB BAR (AMBULATORY STALL)
GB-5	GRAB BAR (SHOWER)
GB-6	GRAB BAR (BACK WALL 24")
GB-7	GRAB BAR (BACK WALL 12")
HD	HAND DRYER
LAV	LAVATORY
MBH	MOPIBROOM HOLDER
MR	MIRROR
MRS	MIRROR WITH SHELF
PTD	PAPER TOWEL DISPENSER
PTDR	COMBINATION TOWEL DISPENSER/RECEPTACLE
RH	ROBE HOOK
SCD	SEAT COVER DISPENSER
SCR	SHOWER CURTAIN ROD
SD	SOAP DISPENSER
SND	SANITARY NAPKIN DISPOSAL
SNV	SANITARY NAPKIN VENDOR
SSS	STAINLESS STEEL SHELF
TTO	TOILET TISSUE DISPENSER
US	UTILITY SHELF
WC	WATER CLOSET
WR	WASTE RECEPTACLE

SHEET NOTES

- NEW BOTTLE FILLER DRINKING FOUNTAIN, REFER MEP DRAWINGS. TOUCH UP, REPAIR AND PREP WALL FOR NEW FINISH WHERE EXISTING DRINKING FOUNTAIN WAS REMOVED.
- EXISTING SALVAGED RE-INSTALLED BOTTLE FILLER / DRINKING FOUNTAIN, REFER MEP DRAWINGS.
- GRAB BARS (GB): PROVIDE INSTALLATION ANCHORING SPECIFICATIONS AS REQUIRED BY MANUFACTURERS STANDARDS FOR GRAB BARS, SHOWER SEATS AND DRESSING ROOM BENCH SEAT SYSTEMS DESIGNED TO RESIST A SINGLE CONCENTRATED LOAD OF 250 LBS APPLIED IN ANY DIRECTION AT ANY POINT PER SECTION 1007.02.
- GC TO PROVIDE 1/2" CEMENT BOARD BACKING ON CONTINUOUS 1/4" ALUMINUM Z-CLIP ANCHORS MOUNTED ON EXISTING CMU AND NEW WALLS WHERE CERAMIC TILE FINISH IS TO BE INSTALLED.

GENERAL ARCHITECTURAL NOTES

- ALL INTERIOR CMU WALLS SHALL BE 8 INCHES NOMINAL THICKNESS, UNLESS NOTED OTHERWISE.
- PARTITION TYPES SHALL BE DESIGNATED ON FLOOR PLANS (XX, X, XX). THIS SEE SHEET AB-2 FOR TYPES. ALL INTERIOR PARTITIONS ARE TYPE SA 3.20 UNLESS NOTED OTHERWISE.
- ALL MASONRY WALLS AND INTERIOR STUD WALLS SHALL EXTEND TO UNDERSIDE OF FLOOR OR ROOF DECK ABOVE UNLESS NOTED OTHERWISE, PER PARTITION TYPE.
- PROVISIONS SHALL BE MADE AT ALL FULL HEIGHT NON-BEARING WALLS FOR 1-INCH VERTICAL MOVEMENT OF THE BUILDING STRUCTURE WITHOUT TRANSFER OF COMPRESSIVE LOADS TO WALL. FILL IRREGULARITIES BETWEEN TOP OF WALL AND DECK ABOVE WITH MINERAL WOOL INSULATION OR FIRE STOPPING MATERIAL AS REQUIRED TO MEET FIRE RATING OF RESPECTIVE WALLS.
- NOT USED.
- FURNISH AND INSTALL FIRE-TREATED WOOD BLOCKING OR METAL BACKING PLATE IN METAL STUD PARTITIONS FOR THE PROPER ANCHORAGE OF ALL WALL ATTACHED ITEMS, I.E. TOILET ACCESSORIES, CASEWORK, MILLWORK, WALL-MOUNTED FIXTURES, MARKER BOARDS, TACK BOARDS, DOOR STOPS, AUDIO VISUAL BRACKETS, AND OTHER WALL ATTACHED ITEMS.
- GYPSON BOARD SURFACES SHALL BE ISOLATED WITH CONTROL JOINTS WHERE SHOWN ON DRAWINGS AND AS DESCRIBED IN THE SPECIFICATIONS.
- MASONRY CONTROL JOINTS (CJ) AND CONTROL JOINTS ABOVE (CA) SHALL BE LOCATED AS SHOWN ON THE FLOOR PLAN AND BUILDING ELEVATIONS, AND WHERE LARGE PLUMBING VENTS OR RISERS OCCUR IN SINGLE WYTHE MASONRY WALLS, AND WHERE MASONRY WALLS BEARING ON THE CONCRETE OR FLOOR SLAB ABUT MASONRY WALLS BEARING ON CONCRETE FOOTINGS OR AS INDICATED ON DRAWINGS.
- NOT USED.
- EXTEND FURRING CHANNELS AND GYPSON BOARD UP 4 INCHES ABOVE FINISHED CEILING ON CMU WALLS.
- SCRIBE GYPSON WALL BOARD OF WALLS AND PARTITIONS TO IRREGULARITIES OF DECK ABOVE. SEAL TIGHTLY AROUND ALL PENETRATIONS.
- NOT USED.

REFLECTED CEILING PLAN GENERAL NOTES

- REFLECTED CEILING PLAN GENERAL NOTES APPLY TO ALL REFLECTED CEILING PLAN SHEETS.
- ALL CEILING GRIDS/PANELS SHALL BE CENTERED IN EACH ROOM UNLESS NOTED OTHERWISE.
- CEILING HEIGHTS ARE NOTED ON THE REFLECTED CEILING PLANS ARE MEASURED FROM THE FINISH FLOOR OF THE ROOM.
- ALL ELECTRICAL FIXTURES, SPEAKERS, SMOKE AND THERMAL DETECTORS, MECHANICAL GRILLES, SPRINKLER HEADS, AND OTHER CEILING MOUNTED DEVICES, SHALL BE CENTERED BETWEEN CEILING GRIDS UNLESS NOTED OTHERWISE. SPRINKLER HEADS SHALL BE WITHIN A 3-INCH RADIUS CENTERED BETWEEN CEILING GRIDS.
- IN ACOUSTICAL CEILING PANELS WITH SCORE IN THE CENTER, CENTER DEVICES REFERENCE IN NOTE D IN ONE HALF OF THE TILE. DO NOT LOCATE ON THE SCORE. FOR ACP WITH MULTIPLE SCORED PATTERNS, COORDINATE LOCATION WITH THE ARCHITECT.
- PROVIDE SUSPENSION SYSTEM AROUND ELECTRICAL FIXTURES, MECHANICAL GRILLES, DIFFUSERS, AND OTHER CEILING MOUNTED DEVICES, AT ACOUSTICAL PANEL CEILINGS.
- ALL DIMENSIONS ON REFLECTED CEILING PLANS ARE ACTUAL AND ARE TO THE FOLLOWING UNLESS NOTED OTHERWISE:
 - FACE OF FINISHED WALL
 - FACE OF FINISHED BULKHEADS
 - CENTERLINE OF COLUMNS
 - CENTERLINE OF TEES
- IN AREAS WITH EXPOSED STRUCTURE CEILINGS, COORDINATE EXACT LOCATIONS OF MECHANICAL GRILLES, DIFFUSERS, DUCTWORK AND ELECTRICAL FIXTURES WITH EACH REPRESENTATIVE SUBCONTRACTOR.
- ALL WALLS EXTENDING TO UNDERSIDE OF DECK EXCEPT THOSE SHOWN SHADED IN WHICH GYPSON BOARD OR MASONRY EXTENDS MIN 4 INCHES ABOVE FINISHED CEILING. ALL METAL STUDS EXTEND TO UNDERSIDE OF FLOOR OR ROOF DECK.

REFLECTED CEILING PLAN LEGEND

CEILING TYPES	DESCRIPTION
	GWB, GYPSON BOARD CEILING
	ACT, ACOUSTICAL CEILING TILE
	CEILING TYPE CEILING HEIGHT


INTERIOR FINISH PLAN GENERAL NOTES

- FINISH SCHEDULE GENERAL NOTES APPLY TO ALL FINISH SCHEDULE SHEETS.
- INTERIOR FINISH PLAN GENERAL NOTES APPLY TO ALL INTERIOR FINISH PLAN SHEETS.
- NOT ALL FLOOR AND WALL FINISHES ARE NOTED ON THE INTERIOR FINISH PLANS.
- FLOOR PATTERN DIMENSIONS AND LOCATIONS ARE APPROXIMATE. MINOR ADJUSTMENTS MAY BE MADE FOR LAYOUT AND TO MINIMIZE WASTE AS LONG AS THE DESIGN INTENT IS MAINTAINED.
- FOR FLOOR TILE PRODUCTS, ADJUST LAYOUT AS NECESSARY TO AVOID USING CUT WIDTHS THAT EQUAL LESS THEN ONE-HALF OF A TILE AT ROOM PERIMETER.
- SEE SPECIFICATION FOR PAINTING OF ITEMS NOT NOTED IN THE FINISH SCHEDULE OR FINISH PLANS.
- EXPOSED CONCRETE FLOORS NOT SHOWN TO RECEIVE A FINISH SHALL RECEIVE LIQUID FLOOR TREATMENT OR CURING AND SEALING COMPOUND UNLESS NOTED OTHERWISE. SEE SPEC SECTION 033000.
- ALL GYPSON WALLBOARD BULKHEADS SHALL BE PAINTED P-01 UNLESS NOTED OTHERWISE.
- SEE REFLECTED CEILING PLANS FOR CEILING MATERIAL AND HEIGHT.
- CEILING HEIGHTS, AS NOTED ON THE REFLECTED CEILING PLANS, ARE MEASURED FROM FINISH FLOOR OF THE ROOM.
- WHERE FLOOR FINISH CHANGES FROM ONE ROOM TO ANOTHER, SET JOINT OF THE MATERIALS AT THE CENTER OF THE COMMUNICATING DOOR, LING.
- PROVIDE EDGE BAND AT ALL EDGES OF MDF DOORS AND DRAWER FRONTS TO MATCH DOOR/DRAWER FINISH. SUBMIT SAMPLE TO ARCHITECT FOR APPROVAL.


FINISH PLAN LEGEND

	AREA NOT IN CONTRACT (NIC)
	PLAN KEYED NOTE
	FLOOR FINISH TRANSITION
	FLOOR MATERIAL DIRECTION
	FINISH MATERIAL TAG
	EXTENT OF WALL FINISH, SEE INTERIOR ELEVATION FOR ADDITIONAL INFORMATION





2A ENLARGED FLOOR PLAN - BOYS 148 / GIRLS 152
SCALE: 1/4" = 1'-0"



2C ENLARGED RCP - BOYS 148 / GIRLS 152
SCALE: 1/4" = 1'-0"

TOILET ACCESSORIES ABBREVIATIONS

ABBREV	DESCRIPTION
ACC	ADA ACCESSIBLE
BCS	BABY CHANGING STATION
EWG	ELECTRIC WATER COOLER
FSS	FOLDING SHOWER SEAT
GB-1	GRAB BAR (BACK WALL)
GB-2	GRAB BAR (SIDE WALL)
GB-3	GRAB BAR (VERTICAL)
GB-4	GRAB BAR (AMBULATORY STALL)
GB-5	GRAB BAR (SHOWER)
GB-6	GRAB BAR (BACK WALL 24")
GB-7	GRAB BAR (BACK WALL 12")
HD	HAND DRYER
LAV	LAVATORY
MBH	MOPIBROOM HOLDER
MR	MIRROR
MRS	MIRROR WITH SHELF
PTD	PAPER TOWEL DISPENSER
PTDR	COMBINATION TOWEL DISPENSER/RECEPTACLE
RH	ROBE HOOK
SCD	SEAT COVER DISPENSER
SCR	SHOWER CURTAIN ROD
SD	SOAP DISPENSER
SND	SANITARY NAPKIN DISPOSAL
SNV	SANITARY NAPKIN VENDOR
SSS	STAINLESS STEEL SHELF
TTD	TOILET TISSUE DISPENSER
US	UTILITY SHELF
WC	WATER CLOSET
WR	WASTE RECEPTACLE

SHEET NOTES

- NEW BOTTLE FILLER DRINKING FOUNTAIN, REFER MEP DRAWINGS. TOUCH UP, REPAIR AND PREP WALL FOR NEW FINISH WHERE EXISTING DRINKING FOUNTAIN WAS REMOVED.
- EXISTING SALVAGED RE-INSTALLED BOTTLE FILLER / DRINKING FOUNTAIN, REFER MEP DRAWINGS.
- GRAB BARS (GB): PROVIDE INSTALLATION ANCHORING SPECIFICATIONS AS REQUIRED BY MANUFACTURERS STANDARDS FOR GRAB BARS, SHOWER SEATS AND DRESSING ROOM BENCH SEAT SYSTEMS DESIGNED TO RESIST A SINGLE CONCENTRATED LOAD OF 250 LBS APPLIED IN ANY DIRECTION AT ANY POINT PER SECTION 1007.02.
- GC TO PROVIDE 1/2" CEMENT BOARD BACKING ON CONTINUOUS 1 1/2" ALUMINUM Z-CLIP ANCHORS MOUNTED ON EXISTING CMU AND NEW WALLS WHERE CERAMIC TILE FINISH IS TO BE INSTALLED.


GENERAL ARCHITECTURAL NOTES

- ALL INTERIOR CMU WALLS SHALL BE 8 INCHES NOMINAL THICKNESS, UNLESS NOTED OTHERWISE.
- PARTITION TYPES SHALL BE DESIGNATED ON FLOOR PLANS (XX.XX). THIS SHEET AB 2 FOR TYPES. ALL INTERIOR PARTITIONS ARE TYPE SA 3.20 UNLESS NOTED OTHERWISE.
- ALL MASONRY WALLS AND INTERIOR STUD WALLS SHALL EXTEND TO UNDERSIDE OF FLOOR OR ROOF DECK ABOVE UNLESS NOTED OTHERWISE, PER PARTITION TYPE.
- PROVISIONS SHALL BE MADE AT ALL FULL HEIGHT NON-BEARING WALLS FOR 1-INCH VERTICAL MOVEMENT OF THE BUILDING STRUCTURE WITHOUT TRANSFER OF COMPRESSIVE LOADS TO WALL. FILL IRREGULARITIES BETWEEN TOP OF WALL AND DECK ABOVE WITH MINERAL INSULATION OR FIRE STOPPING MATERIAL AS REQUIRED TO MEET FIRE RATING OF RESPECTIVE WALLS.
- NOT USED.
- FURNISH AND INSTALL FIRE-TREATED WOOD BLOCKING OR METAL BACKING PLATE IN METAL STUD PARTITIONS FOR THE PROPER ANCHORAGE OF ALL WALL ATTACHED ITEMS, I.E. TOILET ACCESSORIES, CASEWORK, MILLWORK, WALL-MOUNTED FIXTURES, MARKER BOARDS, TACK BOARDS, DOOR STOPS, AUDIO VISUAL BRACKETS, AND OTHER WALL ATTACHED ITEMS.
- GYPSON BOARD SURFACES SHALL BE ISOLATED WITH CONTROL JOINTS WHERE SHOWN ON DRAWINGS AND AS DESCRIBED IN THE SPECIFICATIONS.
- MASONRY CONTROL JOINTS (CJ) AND CONTROL JOINTS ABOVE (CA) SHALL BE LOCATED AS SHOWN ON THE FLOOR PLAN AND BUILDING ELEVATIONS, AND WHERE LARGE PLUMBING VENTS OR RISERS OCCUR IN SINGLE WYTHE MASONRY WALLS, AND WHERE MASONRY WALLS BEARING ON THE CONCRETE OR FLOOR SLAB ABUT MASONRY WALLS BEARING ON CONCRETE FOOTINGS OR AS INDICATED ON DRAWINGS.
- NOT USED.
- EXTEND FURRING CHANNELS AND GYPSON BOARD UP 4 INCHES ABOVE FINISHED CEILING ON CMU WALLS.
- SCRIBE GYPSON WALL BOARD OF WALLS AND PARTITIONS TO IRREGULARITIES OF DECK ABOVE. SEAL TIGHTLY AROUND ALL PENETRATIONS.
- NOT USED.

REFLECTED CEILING PLAN GENERAL NOTES

- REFLECTED CEILING PLAN GENERAL NOTES APPLY TO ALL REFLECTED CEILING PLAN SHEETS.
- ALL CEILING GRIDS/PANELS SHALL BE CENTERED IN EACH ROOM UNLESS NOTED OTHERWISE.
- CEILING HEIGHTS ARE NOTED ON THE REFLECTED CEILING PLANS ARE MEASURED FROM THE FINISH FLOOR OF THE ROOM.
- ALL ELECTRICAL FIXTURES, SPEAKERS, SMOKE AND THERMAL DETECTORS, MECHANICAL GRILLES, SPRINKLER HEADS, AND OTHER CEILING MOUNTED DEVICES, SHALL BE CENTERED BETWEEN CEILING GRIDS UNLESS NOTED OTHERWISE. SPRINKLER HEADS SHALL BE WITHIN A 3-INCH RADIUS CENTERED BETWEEN CEILING GRIDS.
- IN ACOUSTICAL CEILING PANELS WITH SCORE IN THE CENTER, CENTER DEVICES REFERENCE IN NOTE D IN ONE HALF OF THE TILE. DO NOT LOCATE ON THE SCORE. FOR ACP WITH MULTIPLE SCORED PATTERNS, COORDINATE LOCATION WITH THE ARCHITECT.
- PROVIDE SUSPENSION SYSTEM AROUND ELECTRICAL FIXTURES, MECHANICAL GRILLES, DIFFUSERS, AND OTHER CEILING MOUNTED DEVICES. AT ACOUSTICAL PANEL CEILINGS.
- ALL DIMENSIONS ON REFLECTED CEILING PLANS ARE ACTUAL AND ARE TO THE FOLLOWING UNLESS NOTED OTHERWISE:
 - FACE OF FINISHED WALL
 - FACE OF FINISHED BULKHEADS
 - CENTERLINE OF COLUMNS
 - CENTERLINE OF TEES
- IN AREAS WITH EXPOSED STRUCTURE CEILINGS, COORDINATE EXACT LOCATIONS OF MECHANICAL GRILLES, DIFFUSERS, DUCTWORK AND ELECTRICAL FIXTURES WITH EACH REPRESENTATIVE SUBCONTRACTOR.
- ALL WALLS EXTENDING TO UNDERSIDE OF DECK EXCEPT THOSE SHOWN SHADED IN WHICH GYPSON BOARD OR MASONRY EXTENDS MIN 4 INCHES ABOVE FINISHED CEILING. ALL METAL STUDS EXTEND TO UNDERSIDE OF FLOOR OR ROOF DECK.



REFLECTED CEILING PLAN LEGEND




INTERIOR FINISH PLAN GENERAL NOTES

- FINISH SCHEDULE GENERAL NOTES APPLY TO ALL FINISH SCHEDULE SHEETS.
- INTERIOR FINISH PLAN GENERAL NOTES APPLY TO ALL INTERIOR FINISH PLAN SHEETS.
- NOT ALL FLOOR AND WALL FINISHES ARE NOTED ON THE INTERIOR FINISH PLANS.
- FLOOR FINISH DIMENSIONS AND LOCATIONS ARE APPROXIMATE. MINOR ADJUSTMENTS MAY BE MADE FOR LAYOUT AND TO MINIMIZE WASTE AS LONG AS THE DESIGN INTENT IS MAINTAINED.
- FOR FLOOR TILE PRODUCTS, ADJUST LAYOUT AS NECESSARY TO AVOID USING CUT WIDTHS THAT EQUAL LESS THEN ONE-HALF OF A TILE AT ROOM PERIMETER.
- SEE SPECIFICATION FOR PAINTING OF ITEMS NOT NOTED IN THE FINISH SCHEDULE OR FINISH PLANS.
- EXPOSED CONCRETE FLOORS NOT SHOWN TO RECEIVE A FINISH SHALL RECEIVE LIQUID FLOOR TREATMENT OR CURING AND SEALING COMPOUND UNLESS NOTED OTHERWISE. SEE SPEC SECTION 033000.
- ALL GYPSON WALLBOARD BULKHEADS SHALL BE PAINTED P-01 UNLESS NOTED OTHERWISE.
- SEE REFLECTED CEILING PLANS FOR CEILING MATERIAL AND HEIGHT.
- CEILING HEIGHTS, AS NOTED ON THE REFLECTED CEILING PLANS, ARE MEASURED FROM FINISH FLOOR OF THE ROOM.
- WHERE FLOOR FINISH CHANGES FROM ONE ROOM TO ANOTHER, SET JOINT OF THE MATERIALS AT THE CENTER OF THE COMMUNICATING DOOR LING.
- PROVIDE EDGE BAND AT ALL EDGES OF MDF DOORS AND DRAWER FRONTS TO MATCH DOOR/DRAWER FINISH. SUBMIT SAMPLE TO ARCHITECT FOR APPROVAL.


FINISH PLAN LEGEND




4A 148 - BOYS - NORTH
SCALE: 1/4" = 1'-0"




4B 148 - BOYS SOUTH EAST
SCALE: 1/4" = 1'-0"




4C 148 - BOYS - SOUTH
SCALE: 1/4" = 1'-0"




4D 148 - BOYS - WEST
SCALE: 1/4" = 1'-0"




4E DRINKING FOUNTAIN ELEVATION
SCALE: 1/4" = 1'-0"




5A Elevation 1 - a
SCALE: 1/4" = 1'-0"



5B 152 - GIRLS - SOUTH
SCALE: 1/4" = 1'-0"



5C 152 - GIRLS - WEST
SCALE: 1/4" = 1'-0"



11400 BISSONNET STREET
HOUSTON, TX 77069

ISSUE FOR BID & PERMIT
10-31-25
REVISIONS

39-25156-00

ENLARGED FLOOR PLANS AND ELEVATIONS

A2.5

A

B

C

D

E

F

1

2

3

4

5

TOILET ACCESSORIES ABBREVIATIONS

ABBREV	DESCRIPTION
ACC	ADA ACCESSIBLE
BCS	BABY CHANGING STATION
EWG	ELECTRIC WATER COOLER
FSS	FOLDING SHOWER SEAT
GB-1	GRAB BAR (BACK WALL)
GB-2	GRAB BAR (SIDE WALL)
GB-3	GRAB BAR (VERTICAL)
GB-4	GRAB BAR (AMBULATORY STALL)
GB-5	GRAB BAR (SHOWER)
GB-6	GRAB BAR (BACK WALL 24")
GB-7	GRAB BAR (BACK WALL 12")
HD	HAND DRYER
LAV	LAVATORY
MBH	MOPIBROOM HOLDER
MR	MIRROR
MRS	MIRROR WITH SHELF
PTD	PAPER TOWEL DISPENSER
PTDR	COMBINATION TOWEL DISPENSER/RECEPTACLE
RH	ROBE HOOK
SCD	SEAT COVER DISPENSER
SCR	SHOWER CURTAIN ROD
SD	SOAP DISPENSER
SND	SANITARY NAPKIN DISPOSAL
SNV	SANITARY NAPKIN VENDOR
SSS	STAINLESS STEEL SHELF
TTO	TOILET TISSUE DISPENSER
US	UTILITY SHELF
WC	WATER CLOSET
WR	WASTE RECEPTACLE

GENERAL ARCHITECTURAL NOTES

- ALL INTERIOR CMU WALLS SHALL BE 8 INCHES NOMINAL THICKNESS, UNLESS NOTED OTHERWISE.
- PARTITION TYPES SHALL BE DESIGNATED ON FLOOR PLANS (XX, X, XX). THIS SEE SHEET A8.2 FOR TYPES. ALL INTERIOR PARTITIONS ARE TYPE SA 3.20 UNLESS NOTED OTHERWISE.
- ALL MASONRY WALLS AND INTERIOR STUD WALLS SHALL EXTEND TO UNDERSIDE OF FLOOR OR ROOF DECK ABOVE UNLESS NOTED OTHERWISE, PER PARTITION TYPE.
- PROVISIONS SHALL BE MADE AT ALL FULL HEIGHT NON-BEARING WALLS FOR 1-INCH VERTICAL MOVEMENT OF THE BUILDING STRUCTURE WITHOUT TRANSFER OF COMPRESSIVE LOADS TO WALL. FILL IRREGULARITIES BETWEEN TOP OF WALL AND DECK ABOVE WITH MINERAL WOOL INSULATION OR FIRE STOPPING MATERIAL AS REQUIRED TO MEET FIRE RATING OF RESPECTIVE WALLS.
- NOT USED.
- FURNISH AND INSTALL FIRE-TREATED WOOD BLOCKING OR METAL BACKING PLATE IN METAL STUD PARTITIONS FOR THE PROPER ANCHORAGE OF ALL WALL ATTACHED ITEMS, I.E. TOILET ACCESSORIES, CASEWORK, MILLWORK, WALL-MOUNTED FIXTURES, MARKER BOARDS, TACK BOARDS, DOOR STOPS, AUDIO VISUAL BRACKETS, AND OTHER WALL ATTACHED ITEMS.
- GYPHUM BOARD SURFACES SHALL BE ISOLATED WITH CONTROL JOINTS WHERE SHOWN ON DRAWINGS AND AS DESCRIBED IN THE SPECIFICATIONS.
- MASONRY CONTROL JOINTS (CJ) AND CONTROL JOINTS ABOVE (CA) SHALL BE LOCATED AS SHOWN ON THE FLOOR PLAN AND BUILDING ELEVATIONS, AND WHERE LARGE PLUMBING VENTS OR RISERS OCCUR IN SINGLE WYTHE MASONRY WALLS, AND WHERE MASONRY WALLS BEARING ON THE CONCRETE FLOOR SLAB ABUT MASONRY WALLS BEARING ON CONCRETE FOOTINGS OR AS INDICATED ON DRAWINGS.
- NOT USED.
- EXTEND FURRING CHANNELS AND GYPHUM BOARD UP 4 INCHES ABOVE FINISHED CEILING ON CMU WALLS.
- SCRIBE GYPHUM WALL BOARD OF WALLS AND PARTITIONS TO IRREGULARITIES OF DECK ABOVE. SEAL TIGHTLY AROUND ALL PENETRATIONS.
- NOT USED.


SHEET NOTES

- NEW BOTTLE FILLER DRINKING FOUNTAIN, REFER MEP DRAWINGS. TOUCH UP, REPAIR AND PREP WALL FOR NEW FINISH WHERE EXISTING DRINKING FOUNTAIN WAS REMOVED.
- EXISTING SALVAGED RE-INSTALLED BOTTLE FILLER / DRINKING FOUNTAIN, REFER MEP DRAWINGS.
- GRAB BARS (GB): PROVIDE INSTALLATION ANCHORING SPECIFICATIONS AS REQUIRED BY MANUFACTURERS STANDARDS FOR GRAB BARS, SHOWER SEATS AND DRESSING ROOM BENCH SEAT SYSTEMS DESIGNED TO RESIST A SINGLE CONCENTRATED LOAD OF 250 LBS APPLIED IN ANY DIRECTION AT ANY POINT PER SECTION 107.1.2.
- GC TO PROVIDE 1/2" CEMENT BOARD BACKING ON CONTINUOUS 1/4" ALUMINUM Z-CLIP ANCHORS MOUNTED ON EXISTING CMU AND NEW WALLS WHERE CERAMIC TILE FINISH IS TO BE INSTALLED.

REFLECTED CEILING PLAN GENERAL NOTES

- REFLECTED CEILING PLAN GENERAL NOTES APPLY TO ALL REFLECTED CEILING PLAN SHEETS.
- ALL CEILING GRID/PANELS SHALL BE CENTERED IN EACH ROOM UNLESS NOTED OTHERWISE.
- CEILING HEIGHTS ARE NOTED ON THE REFLECTED CEILING PLANS ARE MEASURED FROM THE FINISH FLOOR OF THE ROOM.
- ALL ELECTRICAL FIXTURES, SPEAKERS, SMOKE AND THERMAL DETECTORS, MECHANICAL GRILLES, SPRINKLER HEADS, AND OTHER CEILING MOUNTED DEVICES, SHALL BE CENTERED BETWEEN CEILING GRIDS UNLESS NOTED OTHERWISE. SPRINKLER HEADS SHALL BE WITHIN A 3-INCH RADIUS CENTERED BETWEEN CEILING GRIDS.
- IN ACOUSTICAL CEILING PANELS WITH SCORE IN THE CENTER, CENTER DEVICES REFERENCE IN NOTE D IN ONE HALF OF THE TILE. DO NOT LOCATE ON THE SCORE. FOR ACP WITH MULTIPLE SCORED PATTERNS, COORDINATE LOCATION WITH THE ARCHITECT.
- PROVIDE SUSPENSION SYSTEM AROUND ELECTRICAL FIXTURES, MECHANICAL GRILLES, DIFFUSERS, AND OTHER CEILING MOUNTED DEVICES. AT ACOUSTICAL PANEL CEILINGS.
- ALL DIMENSIONS ON REFLECTED CEILING PLANS ARE ACTUAL AND ARE TO THE FOLLOWING UNLESS NOTED OTHERWISE:
 - FACE OF FINISHED WALL
 - FACE OF FINISHED BULKHEADS
 - CENTERLINE OF COLUMNS
 - CENTERLINE OF TEES
- IN AREAS WITH EXPOSED STRUCTURE CEILINGS, COORDINATE EXACT LOCATIONS OF MECHANICAL GRILLES, DIFFUSERS, DUCTWORK AND ELECTRICAL FIXTURES WITH EACH REPRESENTATIVE SUBCONTRACTOR.
- ALL WALLS EXTENDING TO UNDERSIDE OF DECK EXCEPT THOSE SHOWN SHADED IN WHICH GYPHUM BOARD OR MASONRY EXTENDS MIN 4 INCHES ABOVE FINISHED CEILING. ALL METAL STUDS EXTEND TO UNDERSIDE OF FLOOR OR ROOF DECK.




REFLECTED CEILING PLAN LEGEND



INTERIOR FINISH PLAN GENERAL NOTES


- FINISH SCHEDULE GENERAL NOTES APPLY TO ALL FINISH SCHEDULE SHEETS.
- INTERIOR FINISH PLAN GENERAL NOTES APPLY TO ALL INTERIOR FINISH PLAN SHEETS.
- NOT ALL FLOOR AND WALL FINISHES ARE NOTED ON THE INTERIOR FINISH PLANS.
- FLOOR PATTERN DIMENSIONS AND LOCATIONS ARE APPROXIMATE. MINOR ADJUSTMENTS MAY BE MADE FOR LAYOUT AND TO MINIMIZE WASTE AS LONG AS THE DESIGN INTENT IS MAINTAINED.
- FOR FLOOR TILE PRODUCTS, ADJUST LAYOUT AS NECESSARY TO AVOID USING CUT WITHS THAT EQUAL LESS THEN ONE-HALF OF A TILE AT ROOM PERIMETER.
- SEE SPECIFICATION FOR PAINTING OF ITEMS NOT NOTED IN THE FINISH SCHEDULE OR FINISH PLANS.
- EXPOSED CONCRETE FLOORS NOT SHOWN TO RECEIVE A FINISH SHALL RECEIVE LIQUID FLOOR TREATMENT OR CURING AND SEALING COMPOUND UNLESS NOTED OTHERWISE. SEE SPEC SECTION 033000.
- ALL GYPHUM WALLBOARD BULKHEADS SHALL BE PAINTED P-01 UNLESS NOTED OTHERWISE.
- SEE REFLECTED CEILING PLANS FOR CEILING MATERIAL AND HEIGHT.
- CEILING HEIGHTS, AS NOTED ON THE REFLECTED CEILING PLANS, ARE MEASURED FROM FINISH FLOOR OF THE ROOM.
- WHERE FLOOR FINISH CHANGES FROM ONE ROOM TO ANOTHER, SET JOINT OF THE MATERIALS AT THE CENTER OF THE COMMUNICATING DOOR, LING.
- PROVIDE EDGE BAND AT ALL EDGES OF MDF DOORS AND DRAWER FRONTS TO MATCH DOOR/DRAWER FINISH. SUBMIT SAMPLE TO ARCHITECT FOR APPROVAL.

FINISH PLAN LEGEND




2A ENLARGED FLOOR PLAN - GIRLS 170 / BOYS 173
SCALE: 1/4" = 1'-0"


2B ENLARGED RCP - GIRLS 170 / BOYS 173
SCALE: 1/4" = 1'-0"




4B 170 - BOYS - EAST
SCALE: 1/4" = 1'-0"




4C 170 - BOYS - WEST
SCALE: 1/4" = 1'-0"




4D 170 - BOYS - NORTH
SCALE: 1/4" = 1'-0"




4E ELEVATION @ DRINKING FOUNTAIN
SCALE: 1/4" = 1'-0"




5A EAST ELEVATION - GIRLS 173
SCALE: 1/4" = 1'-0"



5B SOUTH ELEVATION - GIRLS 173
SCALE: 1/4" = 1'-0"



5C 173 - GIRLS - WEST
SCALE: 1/4" = 1'-0"



5D 173 - GIRLS - NORTH
SCALE: 1/4" = 1'-0"




BOONE ELEMENTARY SCHOOL
ALIEF INDEPENDENT SCHOOL DISTRICT
11400 BISSONNET STREET
HOUSTON, TX 77066


ISSUE FOR BID & PERMIT
10-31-25
REVISIONS

39-25156-00
ENLARGED FLOOR PLANS AND ELEVATIONS


A2.6




1A ENLARGED FLOOR PLAN - KITCHEN RESTROOM
SCALE: 1/4" = 1'-0"




1B ENLARGED RCP - KITCHEN RESTROOM
SCALE: 1/4" = 1'-0"




2A A108 - KITCHEN RESTROOM - NORTH
SCALE: 1/4" = 1'-0"



2B A108 - KITCHEN RESTROOM - EAST
SCALE: 1/4" = 1'-0"



2C A108 - KITCHEN RESTROOM - SOUTH
SCALE: 1/4" = 1'-0"



2D A108 - KITCHEN RESTROOM - WEST
SCALE: 1/4" = 1'-0"

TOILET ACCESSORIES ABBREVIATIONS

ABBREV	DESCRIPTION
ACC	ADA ACCESSIBLE
BCS	BABY CHANGING STATION
EWG	ELECTRIC WATER COOLER
FSS	FOLDING SHOWER SEAT
GB-1	GRAB BAR (BACK WALL)
GB-2	GRAB BAR (SIDE WALL)
GB-3	GRAB BAR (VERTICAL)
GB-4	GRAB BAR (AMBULATORY STALL)
GB-5	GRAB BAR (SHOWER)
GB-6	GRAB BAR (BACK WALL 24")
GB-7	GRAB BAR (BACK WALL 12")
HD	HAND DRYER
LAV	LAVATORY
MBH	MOPIBROOM HOLDER
MR	MIRROR
MRS	MIRROR WITH SHELF
PTD	PAPER TOWEL DISPENSER
PTDR	COMBINATION TOWEL DISPENSER/RECEPTACLE
RH	ROBE HOOK
SCD	SEAT COVER DISPENSER
SCR	SHOWER CURTAIN ROD
SD	SOAP DISPENSER
SND	SANITARY NAPKIN DISPOSAL
SNV	SANITARY NAPKIN VENDOR
SSS	STAINLESS STEEL SHELF
TTD	TOILET TISSUE DISPENSER
US	UTILITY SHELF
WC	WATER CLOSET
WR	WASTE RECEPTACLE

SHEET NOTES

- NEW BOTTLE FILLER DRINKING FOUNTAIN, REFER MEP DRAWINGS. TOUCH UP, REPAIR AND PREP WALL FOR NEW FINISH WHERE EXISTING DRINKING FOUNTAIN WAS REMOVED.
- EXISTING SALVAGED RE-INSTALLED BOTTLE FILLER / DRINKING FOUNTAIN, REFER MEP DRAWINGS.
- GRAB BARS (GB): PROVIDE INSTALLATION ANCHORING SPECIFICATIONS AS REQUIRED BY MANUFACTURERS STANDARDS FOR GRAB BARS, SHOWER SEATS AND DRESSING ROOM BENCH SEAT SYSTEMS DESIGNED TO RESIST A SINGLE CONCENTRATED LOAD OF 250 LBS APPLIED IN ANY DIRECTION AT ANY POINT PER SECTION 1007.02.
- GC TO PROVIDE 1/2" CEMENT BOARD BACKING ON CONTINUOUS 1/4" ALUMINUM Z-CLIP ANCHORS MOUNTED ON EXISTING CMU AND NEW WALLS WHERE CERAMIC TILE FINISH IS TO BE INSTALLED.


GENERAL ARCHITECTURAL NOTES

- ALL INTERIOR CMU WALLS SHALL BE 8 INCHES NOMINAL THICKNESS, UNLESS NOTED OTHERWISE.
- PARTITION TYPES SHALL BE DESIGNATED ON FLOOR PLANS (XX, X, XX). THIS SEE SHEET A8.2 FOR TYPES. ALL INTERIOR PARTITIONS ARE TYPE SA 3.20 UNLESS NOTED OTHERWISE.
- ALL MASONRY WALLS AND INTERIOR STUD WALLS SHALL EXTEND TO UNDERSIDE OF FLOOR OR ROOF DECK ABOVE UNLESS NOTED OTHERWISE, PER PARTITION TYPE.
- PROVISIONS SHALL BE MADE AT ALL FULL HEIGHT NON-BEARING WALLS FOR 1-INCH VERTICAL MOVEMENT OF THE BUILDING STRUCTURE WITHOUT TRANSFER OF COMPRESSIVE LOADS TO WALL. FILL IRREGULARITIES BETWEEN TOP OF WALL AND DECK ABOVE WITH MINERAL WOOL INSULATION OR FIRE STOPPING MATERIALS AS REQUIRED TO MEET FIRE RATING OF RESPECTIVE WALLS.
- NOT USED.
- FURNISH AND INSTALL FIRE-TREATED WOOD BLOCKING OR METAL BACKING PLATE IN METAL STUD PARTITIONS FOR THE PROPER ANCHORAGE OF ALL WALL ATTACHED ITEMS, I.E. TOILET ACCESSORIES, CASEWORK, MILLWORK, WALL-MOUNTED FIXTURES, MARKER BOARDS, TACK BOARDS, DOOR STOPS, AUDIO VISUAL BRACKETS, AND OTHER WALL ATTACHED ITEMS.
- GYPHUM BOARD SURFACES SHALL BE ISOLATED WITH CONTROL JOINTS WHERE SHOWN ON DRAWINGS AND AS DESCRIBED IN THE SPECIFICATIONS.
- MASONRY CONTROL JOINTS (CJ) AND CONTROL JOINTS ABOVE (CA) SHALL BE LOCATED AS SHOWN ON THE FLOOR PLAN AND BUILDING ELEVATIONS, AND WHERE LARGE PLUMBING VENTS OR RISERS OCCUR IN SINGLE WYTHE MASONRY WALLS, AND WHERE MASONRY WALLS BEARING ON THE CONCRETE OR FLOOR SLAB ABUT MASONRY WALLS BEARING ON CONCRETE FOOTINGS OR AS INDICATED ON DRAWINGS.
- NOT USED.
- EXTEND FURRING CHANNELS AND GYPSUM BOARD UP 4 INCHES ABOVE FINISHED CEILING ON CMU WALLS.
- SCRIBE GYPSUM WALL BOARD OF WALLS AND PARTITIONS TO IRREGULARITIES OF DECK ABOVE. SEAL TIGHTLY AROUND ALL PENETRATIONS.
- NOT USED.

REFLECTED CEILING PLAN GENERAL NOTES

- REFLECTED CEILING PLAN GENERAL NOTES APPLY TO ALL REFLECTED CEILING PLAN SHEETS.
- ALL CEILING GRID/PANELS SHALL BE CENTERED IN EACH ROOM UNLESS NOTED OTHERWISE.
- CEILING HEIGHTS ARE NOTED ON THE REFLECTED CEILING PLANS ARE MEASURED FROM THE FINISH FLOOR OF THE ROOM.
- ALL ELECTRICAL FIXTURES, SPEAKERS, SMOKE AND THERMAL DETECTORS, MECHANICAL GRILLES, SPRINKLER HEADS, AND OTHER CEILING MOUNTED DEVICES, SHALL BE CENTERED BETWEEN CEILING GRIDS UNLESS NOTED OTHERWISE. SPRINKLER HEADS SHALL BE WITHIN A 3-INCH RADIUS CENTERED BETWEEN CEILING GRIDS.
- IN ACOUSTICAL CEILING PANELS WITH SCORE IN THE CENTER, CENTER DEVICES REFERENCE IN NOTE D IN ONE HALF OF THE TILE. DO NOT LOCATE ON THE SCORE. FOR ACP WITH MULTIPLE SCORE PATTERNS, COORDINATE LOCATION WITH THE ARCHITECT.
- PROVIDE SUSPENSION SYSTEM AROUND ELECTRICAL FIXTURES, MECHANICAL GRILLES, DIFFUSERS, AND OTHER CEILING MOUNTED DEVICES. AT ACOUSTICAL PANEL CEILINGS.
- ALL DIMENSIONS ON REFLECTED CEILING PLANS ARE ACTUAL AND ARE TO THE FOLLOWING UNLESS NOTED OTHERWISE:
 - FACE OF FINISHED WALL
 - FACE OF FINISHED BULKHEADS
 - CENTERLINE OF COLUMNS
 - CENTERLINE OF TEES
- IN AREAS WITH EXPOSED STRUCTURE CEILINGS, COORDINATE EXACT LOCATIONS OF MECHANICAL, GRILLES, DIFFUSERS, DUCTWORK AND ELECTRICAL FIXTURES WITH EACH REPRESENTATIVE SUBCONTRACTOR.
- ALL WALLS EXTENDING TO UNDERSIDE OF DECK EXCEPT THOSE SHOWN SHADED IN WHICH GYPSUM BOARD OR MASONRY EXTENDS MIN 4 INCHES ABOVE FINISHED CEILING. ALL METAL STUDS EXTEND TO UNDERSIDE OF FLOOR OR ROOF DECK.



REFLECTED CEILING PLAN LEGEND



INTERIOR FINISH PLAN GENERAL NOTES

- FINISH SCHEDULE GENERAL NOTES APPLY TO ALL FINISH SCHEDULE SHEETS.
- INTERIOR FINISH PLAN GENERAL NOTES APPLY TO ALL INTERIOR FINISH PLAN SHEETS.
- NOT ALL FLOOR AND WALL FINISHES ARE NOTED ON THE INTERIOR FINISH PLANS.
- FLOOR PATTERN DIMENSIONS AND LOCATIONS ARE APPROXIMATE. MINOR ADJUSTMENTS MAY BE MADE FOR LAYOUT AND TO MINIMIZE WASTE AS LONG AS THE DESIGN INTENT IS MAINTAINED.
- FOR FLOOR TILE PRODUCTS, ADJUST LAYOUT AS NECESSARY TO AVOID USING CUT WIDTHS THAT EQUAL LESS THEN ONE-HALF OF A TILE AT ROOM PERIMETER.
- SEE SPECIFICATION FOR PAINTING OF ITEMS NOT NOTED IN THE FINISH SCHEDULE OR FINISH PLANS.
- EXPOSED CONCRETE FLOORS NOT SHOWN TO RECEIVE A FINISH SHALL RECEIVE LIQUID FLOOR TREATMENT OR CURING AND SEALING COMPOUND UNLESS NOTED OTHERWISE. SEE SPEC SECTION 03300.
- ALL GYPSUM WALLBOARD BULKHEADS SHALL BE PAINTED P-01 UNLESS NOTED OTHERWISE.
- SEE REFLECTED CEILING PLANS FOR CEILING MATERIAL AND HEIGHT.
- CEILING HEIGHTS, AS NOTED ON THE REFLECTED CEILING PLANS, ARE MEASURED FROM FINISH FLOOR OF THE ROOM.
- WHERE FLOOR FINISH CHANGES FROM ONE ROOM TO ANOTHER, SET JOINT OF THE MATERIALS AT THE CENTER OF THE COMMUNICATING DOOR LING.
- PROVIDE EDGE BAND AT ALL EDGES OF MDF DOORS AND DRAWER FRONTS TO MATCH DOOR/DRAWER FINISH. SUBMIT SAMPLE TO ARCHITECT FOR APPROVAL.

FINISH PLAN LEGEND



BOONE ELEMENTARY SCHOOL
ALIEF INDEPENDENT SCHOOL DISTRICT
11400 BISSONNET STREET
HOUSTON, TX 77066

ISSUE FOR BID & PERMIT
10-31-25
REVISIONS


1 12-17-25 CCH COMMENTS
2 01-15-26 TMS CCH COMMENTS
3 03-11-26 ISSUE FOR BID & PERMIT
4 02-25-26 ADD 3 BID AGENDA

39-25156-00
ENLARGED FLOOR PLANS AND ELEVATIONS


A2.7

NUMBER	NO. OF PANELS	PANEL					FRAME		FIRE RATING	HARDWARE SET	DETAILS				COMMENTS
		WIDTH	HEIGHT	THICKNESS	MATERIAL	GLASS	TYPE	MATERIAL			TYPE	HEAD	JAMB LEFT	JAMB RIGHT	
A108	1	3'-0"	7'-0"	1 3/4"	WD		F	HM	1	341	2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	DOOR PLANT TO MATCH EXISTING, OMIT CLOSER
A148A		3'-0"	9'-9" VIF				HM	1	002	002	2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING W/ TRANSOM TO MATCH EXISTING, REFER SAAB.2
A152		3'-0"	7'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING
A152A		3'-0"	9'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING W/ TRANSOM TO MATCH EXISTING, REFER SAAB.2
A170A		3'-0"	9'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING W/ TRANSOM TO MATCH EXISTING, REFER SAAB.2
A173		3'-0"	7'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING
A173A		3'-0"	9'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING W/ TRANSOM TO MATCH EXISTING, REFER SAAB.2
A187		3'-0"	7'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING
A187A		3'-0"	9'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING W/ TRANSOM TO MATCH EXISTING, REFER SAAB.2
A190A		3'-0"	9'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING W/ TRANSOM TO MATCH EXISTING, REFER SAAB.2
A218A		3'-0"	9'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING W/ TRANSOM TO MATCH EXISTING, REFER SAAB.2
A222		3'-0"	7'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING
A222A		3'-0"	9'-9" VIF				HM	1	002		2A/A8.2	2B/A8.2	2B/A8.2 O.H.	2C/A8.2	CASED OPENING W/ TRANSOM TO MATCH EXISTING, REFER SAAB.2

DOOR PANEL TYPES



INTERIOR FRAME TYPES



MARK	ROUGH THICKNESS	FIRE/SMOKE		SOUND		T.O. WALL DETAIL	B.O. WALL DETAIL	COMMENTS
		RATING	TESTED ASSEMBLIES	STC RATING	TESTED ASSEMBLIES			
MA 4	00	3 5/8"	NR	NA				
MA 6	00	5 5/8"	NR	NA				

DOOR AND FRAME SCHEDULE GENERAL NOTES

- A. NOT USED.
- B. ALL INTERIOR HOLLOW METAL FRAMES SET IN MASONRY AND CONCRETE WALLS SHALL BE GROUTED SOLID.
- C. ALL HOLLOW METAL FRAMES SET IN METAL STUD WALLS SHALL BE FILLED WITH MINERAL WOOL BLANKET INSULATION.
- D. NOT USED.
- E. NOT USED.
- F. GLASS TYPES FOR DOORS ARE INDICATED IN THE DOOR GLAZING COLUMN OF THE DOOR AND FRAME SCHEDULE. GLASS TYPES FOR FRAMES ARE INDICATED ON THE FRAME ELEVATIONS.
- G. NOT USED.
- H. FRAME MANUFACTURER SHALL COORDINATE LOCATIONS OF ALL CONCEALED CONDUIT AND J-BOXES REQUIRED FOR SECURITY SYSTEM HARDWARE PRIOR TO MANUFACTURING OF HOLLOW METAL FRAMES AND COORDINATE WITH SECURITY HARDWARE AND DEVICES.
- I. NOT USED.
- J. SEE SPECIFICATIONS HARDWARE SECTION FOR HARDWARE SETS NOTED IN DOOR AND FRAME SCHEDULE.

DOOR PANEL TYPE DESCRIPTIONS

- DC DUAL LITE GLASS
- F FLUSH PANEL
- FG FULL LITE GLASS
- FL FULL LOUVERED
- G HALF LITE GLASS
- GL HALF LITE GLASS & LOUVERED
- L LOUVERED (BOTTOM)
- LL LOUVERED (TOP & BOTTOM)
- N NARROW LITE GLASS
- NL NARROW LITE GLASS & LOUVERED
- TL LOUVERED (TOP)
- V VISION LITE GLASS (10" SQUARE)
- VL VISION LITE GLASS & LOUVERED

PARTITION TYPES DESCRIPTIONS

- MATERIAL DESCRIPTION**
- S = STEEL (METAL STUDS)
 - W = WOOD STUDS
 - H = SHAFT WALLS
 - M = MASONRY
 - C = CONCRETE
- RATING / HEIGHT**
- A = FULL HEIGHT / UNDERSIDE OF STRUCT (NOT RATED)
 - B = 6' ABOVE CEILING (NOT RATED)
 - C = UNDERSIDE OF CEILING (NOT RATED)
 - D = PARTIAL HEIGHT (NOT RATED)
 - X = VARIABLE HEIGHT (NOT RATED)
 - S = SMOKE PARTITION (NOT RATED)
 - 0 = 0 HOUR RATED (CORRIDOR)
 - 5 = 0.5 HOUR RATED
 - 1 = 1 HOUR RATED
 - 2 = 2 HOUR RATED
 - 3 = 3 HOUR RATED
 - 4 = 4 HOUR RATED
- UNIT WIDTH / CONFIGURATION**
- F = FURRING STRIPS / CHANNELS
 - 1 = 1 5/8" METAL
 - 2 = 2 1/2" METAL / 1 1/2" WOOD
 - 3 = 3 5/8" METAL
 - 4 = 4" METAL / 3 1/2" WOOD / 3 5/8" CMU
 - 6 = 6" METAL / 5 1/2" WOOD / 5 5/8" CMU / 6" CONC
 - 8 = 8" METAL / 7 1/4" WOOD / 7 5/8" CMU / 8" CONC
 - 10 = 10" CONC
 - 12 = 11 5/8" CMU / 12" CONC
 - X = NON-STANDARD WIDTH, SEE DETAILS
 - D = DOUBLE STUD FRAMING
 - S = STAGGERED STUD FRAMING
- GLYPH WALL BOARD INDICATOR (NOT INCLUDING SHAFT LINER)**
- 0 = NO GWB
 - 1 = ONE LAYER, TAG SIDE
 - 2 = ONE LAYER, EACH SIDE
 - 3 = TWO LAYERS TAG SIDE, ONE LAYER OTHER
 - 4 = TWO LAYERS, EACH SIDE
 - 5 = TWO LAYERS TAG SIDE, NO GWB OTHER
 - 6 = THREE LAYERS, EACH SIDE

NOTE:
GC TO PAINT ALL DOOR FRAMES AND CASED OPENINGS TOUCHED BY THIS RENOVATION PROJECT (EXISTING OR NEW), TO MATCH ADJACENT WALL COLOR.
GC TO FIELD VERIFY EXISTING DOOR OPENINGS AND COORDINATE NEW OPENINGS WITH EXISTING.


HARDWARE GROUP:
HARDWARE GROUP NO 002 - CASED OPEN
PROVIDE EACH CASED OPENING WITH THE FOLLOWING:

QTY	DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA HINGE	5BB1 4.5 X 4.5	652	N/E
1	EA PRIVACY W/ INDICATOR	MA31 OCCUPIED/VACANT CMM	626	FAL
1	EA SURFACE CLOSER	4040XP RWP/AVEDA TBSRTX-MTG	989	LON


HARDWARE GROUP NO 341 - SGL PRIV RR W/ INDICATOR
PROVIDE EACH SGL DOOR(S) WITH THE FOLLOWING:

QTY	DESCRIPTION	CATALOG NUMBER	FINISH	MFR
1	EA KICK PLATE	8400 10" X 2" LDW B-CS	630	N/E
1	EA WALL STOP	WS40640Y CCV	630	N/E
1	EA GASKETING	4888BK PSA H & J	BK	ZER


OMIT CLOSER AT DOOR A108




2A HM DOOR HEAD
SCALE: 1 1/2" = 1'-0"



2B HM DOOR JAMB
SCALE: 1 1/2" = 1'-0"



2C HM DOOR SILL
SCALE: 1 1/2" = 1'-0"



PROVIDE TRANSOM AT NEW CASED OPENINGS TO MATCH EXISTING CONDITIONS

MATCH EXISTING FRAME HEIGHT AND WIDTH AND DELETE DOOR AT NEW CASED OPENINGS

5A EXISTING OPENING - MATCH
SCALE: 3" = 1'-0"


ISSUE FOR BID & PERMIT
10-31-25
REVISIONS

- 1 12-17-25 CCH COMMENTS
- 2 01-15-26 TMS CCH COMMENTS
- 3 03-11-26 ISSUE FOR BID & PERMIT
- 4 02-25-26 ADD 3 BID AGENDA

BOONE ELEMENTARY SCHOOL
ALIEF INDEPENDENT SCHOOL DISTRICT
11400 BISSONNET STREET
HOUSTON, TX 77066

39-25156-00
DOOR & FRAME TYPE & SCHEDULE

A8.2



DLR Group inc. of Texas
a Texas corporation
2500 Pacific Avenue, Suite 1600
Dallas, Texas 75226

ALIEF ISD
HEFLIN ES – RESTROOM RENOVATIONS
HOUSTON, TX

DLR GROUP PROJECT NO. 39-25156-00

<TYPE OF CONTRACT>
02-25-26

NOTICE TO BIDDERS/CONTRACTOR: Amend the Project Manuals and Drawings to the above referenced project as follows:

PROJECT MANUAL

ITEM NO. 1. NA

DRAWINGS

ITEM NO. 1. SHEET A2.1 – ENLARGED FLOOR PLANS & ELEVATIONS

- A. Drawing 3A, 3B, 3C, 3D, 4A, 4B, 4C & 4D adjust the height of ceiling as shown and noted.

END OF ADDENDA 6

ALIEF ISD


ALIEF MIDDLE SCHOOL - RESTROOM RENOVATIONS - PACKAGE I

4415 COOK ROAD
HOUSTON, TX 77072

ISSUE FOR BID & PERMIT
MAY 6, 2025



PROJECT LOCATION



PROJECT ADDRESS:
4415 COOK ROAD
HOUSTON, TX 77072



PROJECT INFORMATION

SCOPE OF WORK: THE SCOPE OF THIS PROJECT IS AN INTERIOR IMPROVEMENT OF SELECT EXISTING RESTROOMS WITHIN AN EXISTING MIDDLE SCHOOL. WORK TO INCLUDE NEW WALLS, CEILINGS, DOORS, MILLWORK AND FINISHES, WITH SOME MECHANICAL, ELECTRICAL AND PLUMBING ADJUSTMENTS.
NO CHANGE TO OCCUPANCY TYPE.

GOVERNING CODES & REGULATIONS:
GOVERNING AHJ: CITY OF HOUSTON STATE OF TEXAS
BUILDING CODE: 2021 INTERNATIONAL BUILDING CODE (W/ HOUSTON AMENDMENTS)
MECHANICAL CODE: 2021 UNIFORM MECHANICAL CODE (W/ HOUSTON AMENDMENTS)
ELECTRICAL CODE: 2023 NATIONAL ELECTRICAL CODE
PLUMBING CODE: 2021 UNIFORM PLUMBING CODE (W/ HOUSTON AMENDMENTS)
FIRE CODE: 2021 INTERNATIONAL FIRE CODE (W/ HOUSTON AMENDMENTS)
ENERGY CODE: 2021 INTERNATIONAL ENERGY CONSERVATION CODE (W/ HOUSTON AMENDMENTS)
ACCESSIBILITY: 2012 TEXAS ACCESSIBILITY STANDARDS

TABS#: 2025018385

BUILDING OWNER: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefisd.net

PROJECT TEAM

CLIENT NAME: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefisd.net

OWNER'S REPRESENTATIVE: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefisd.net

ARCHITECT: DLR GROUP
1000 LOUISIANA STREET, SUITE 1100
HOUSTON, TX 77002
AJ SUSTAITA
713.561.3825
asustaita@dlr.com

MEP ENGINEER: DBR INC.
9900 RICHMOND AVE, SUITE 300
HOUSTON, TX 77042
BRENT MOE
713.914.0889
bmoe@dbrrc.com

ALTERNATE PRICING

1 X
2 X


DEFERRED SUBMITTALS

NA

KEY PLANS



LEVEL 1



LEVEL 2



SHEET INDEX & ISSUE SCHEDULE

GENERAL		MECHANICAL	
G0.1	COVER SHEET	M0.01	MECHANICAL SYMBOL LEGEND
		M0.11	MECHANICAL GENERAL NOTES & DETAILS
		M2.11	LEVEL 01 - MECHANICAL PLAN
		M2.21	LEVEL 02 - MECHANICAL PLAN
CP1.0	TEXAS ADA	M3.01	LEVEL 01 - MECHANICAL PLAN - ENLARGED
CP1.1	LEVEL 01 - CODE PLAN	M3.02	LEVEL 02 - MECHANICAL PLAN - ENLARGED
CP1.2	LEVEL 02 - CODE PLAN		
ARCHITECTURAL		PLUMBING	
A0.1	GENERAL NOTES, ARCHITECTURAL SYMBOLS & ABBREVIATIONS	P0.01	PLUMBING SYMBOL LEGEND
A0.11	OVERALL LEVEL 01 - DEMOLITION PLAN	P0.11	PLUMBING GENERAL NOTES
A0.12	OVERALL LEVEL 02 - DEMOLITION PLAN	P2.11	LEVEL 01 - DEMOLITION PLUMBING PLAN
A0.21	ENLARGED LEVEL 01 - DEMOLITION PLANS	P2.12	LEVEL 02 - DEMOLITION PLUMBING PLAN
A0.22	ENLARGED LEVEL 02 - DEMOLITION PLANS	P2.21	LEVEL 01 - PLUMBING PLAN
A1.1	LEVEL 01 - OVERALL FLOOR PLAN	P2.22	LEVEL 02 - PLUMBING PLAN
A1.2	LEVEL 02 - OVERALL FLOOR PLAN	P3.01	LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED
A2.1	ACCESSIBILITY MOUNTING HEIGHTS	P3.02	LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED
A2.2	ENLARGED FLOOR PLANS & ELEVATIONS	P3.03	LEVEL 02 - DEMOLITION PLUMBING PLAN - ENLARGED
A2.5	ENLARGED FLOOR PLANS & ELEVATIONS	P3.04	LEVEL 01 - PLUMBING PLAN - ENLARGED
A2.6	ENLARGED FLOOR PLANS & ELEVATIONS	P3.05	LEVEL 01 - PLUMBING PLAN - ENLARGED
A2.8	ENLARGED FLOOR PLANS & ELEVATIONS	P3.06	LEVEL 02 - PLUMBING PLAN - ENLARGED
A2.9	ENLARGED FLOOR PLANS & ELEVATIONS	P5.01	PLUMBING SCHEDULES
A2.10	ENLARGED FLOOR PLANS & ELEVATIONS	P6.01	PLUMBING DETAILS
A2.11	ENLARGED FLOOR PLANS & ELEVATIONS		
A3.1	LEVEL 01 - OVERALL - REFLECTED CEILING PLAN		
A3.2	LEVEL 02 - OVERALL REFLECTED CEILING PLAN		
A8.2	DOOR & FRAME TYPE & SCHEDULE		
A12.01	FINISH SCHEDULES		
A14.1	LEVEL 01 - SIGNAGE PLAN		
		ELECTRICAL	
		E0.01	ELECTRICAL SYMBOL LEGEND
		E0.11	ELECTRICAL GENERAL NOTES
		E1.11	LEVEL 01 - COMPOSITE ELECTRICAL LIGHTING PLAN - DEMO & NEW
		E1.21	LEVEL 02 - COMPOSITE ELECTRICAL LIGHTING PLAN - DEMO & NEW
		E2.11	LEVEL 01 - COMPOSITE ELECTRICAL POWER PLAN - DEMO & NEW
		E2.21	LEVEL 02 - COMPOSITE ELECTRICAL POWER PLAN - DEMO & NEW
		E3.01	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.02	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.03	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.04	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.05	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.06	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.07	LEVEL 02 - ELECTRICAL PLANS - ENLARGED
		E3.08	LEVEL 02 - ELECTRICAL PLANS - ENLARGED
		E5.01	ELECTRICAL SCHEDULES & DETAILS
		E5.02	ELECTRICAL PANEL SCHEDULES

ALIEF MIDDLE - RESTROOM RENOVATIONS
ALIEF INDEPENDENT SCHOOL DISTRICT
4415 COOK ROAD
HOUSTON, TX 77072

ISSUE FOR BID & PERMIT
05.06.2025
REVISIONS

ADD 5 10:31:25 CLIENT VE
6 02:11:26 ISSUE FOR BID & PERMIT


39-25156-00

COVER SHEET

G0.1

A	AE ARCHITECT/ENGINEER AB AIR BARRIER ABS ASBESTOS ACC ADA ACCESSIBLE ACR ACRYLIC ACT ACoustic CEILING TILE AD ACCESS DOOR ADJ ADJUSTABLE ADJT ADJACENT ADMIN ADMINISTRATION AEC AUTOMATED EXTERNAL DEFIBRILLATORS AL ALUMINUM ALUM ALUMINUM AP ACCESS PANEL APC ACOUSTIC PANEL CEILING ASPH ASPHALT AUTO AUTOMATIC AVG AVERAGE AWP ACQUOTIC WALL PANEL	B	GD GARBAGE DISPOSAL GEN GENERAL GFA GROSS FLOOR AREA GL GLUE LAMINATED GLASS GMP GUARANTEED MAXIMUM PRICE GR GUARD RAIL GR GRADE GRS GALVANIZED RIGID STEEL GWB GYPSUM WALL BOARD GYP GYPSUM	C	SC SHOWER CURTAIN SCD SEAT COVER DISPENSER SCH SHOWER CURTAIN HOOK SCR SHOWER CURTAIN ROD SCT STRUCTURAL CLAY TILE SECY SOAP DISPENSER SF SECRETARY SF SQUARE FEET SG SPANDREL GLASS SG SPECIALTY GLASS SGL SINGLE SGV SINGLE GAS VALVE SR SURFACE SHM SECURITY HOLLOW METAL SLNT SEALANT SM SHEET METAL SND SANITARY NAPKIN DISPOSAL SNV SANITARY NAPKIN VENDOR SO SENSOR OPERATED SPL SOUND PRESSURE LEVEL SQ SQUARE SR SURFACE MOUNTED ELECTRICAL RACEWAY SS SOLID SURFACE SSA STORM SHELTER AREA SSM SOLID SURFACE SSS STAINLESS STEEL SHELF SST STAINLESS STEEL ST STONE ST STAIR STAGD STAGGERED STC SOUND TRANSMISSION CLASS STGR STAIR SUBFL SUBFLOOR SULPHUR SULPHUR SURF SURFACE SUSP SUSPENDED SVF SHEET VINYL FLOORING SVF SERVICE FIXTURE SVG SERVICE FIXTURE GROUP	D	GD GARBAGE DISPOSAL GEN GENERAL GFA GROSS FLOOR AREA GL GLUE LAMINATED GLASS GMP GUARANTEED MAXIMUM PRICE GR GUARD RAIL GR GRADE GRS GALVANIZED RIGID STEEL GWB GYPSUM WALL BOARD GYP GYPSUM	E	SC SHOWER CURTAIN SCD SEAT COVER DISPENSER SCH SHOWER CURTAIN HOOK SCR SHOWER CURTAIN ROD SCT STRUCTURAL CLAY TILE SECY SOAP DISPENSER SF SECRETARY SF SQUARE FEET SG SPANDREL GLASS SG SPECIALTY GLASS SGL SINGLE SGV SINGLE GAS VALVE SR SURFACE SHM SECURITY HOLLOW METAL SLNT SEALANT SM SHEET METAL SND SANITARY NAPKIN DISPOSAL SNV SANITARY NAPKIN VENDOR SO SENSOR OPERATED SPL SOUND PRESSURE LEVEL SQ SQUARE SR SURFACE MOUNTED ELECTRICAL RACEWAY SS SOLID SURFACE SSA STORM SHELTER AREA SSM SOLID SURFACE SSS STAINLESS STEEL SHELF SST STAINLESS STEEL ST STONE ST STAIR STAGD STAGGERED STC SOUND TRANSMISSION CLASS STGR STAIR SUBFL SUBFLOOR SULPHUR SULPHUR SURF SURFACE SUSP SUSPENDED SVF SHEET VINYL FLOORING SVF SERVICE FIXTURE SVG SERVICE FIXTURE GROUP	F	SC SHOWER CURTAIN SCD SEAT COVER DISPENSER SCH SHOWER CURTAIN HOOK SCR SHOWER CURTAIN ROD SCT STRUCTURAL CLAY TILE SECY SOAP DISPENSER SF SECRETARY SF SQUARE FEET SG SPANDREL GLASS SG SPECIALTY GLASS SGL SINGLE SGV SINGLE GAS VALVE SR SURFACE SHM SECURITY HOLLOW METAL SLNT SEALANT SM SHEET METAL SND SANITARY NAPKIN DISPOSAL SNV SANITARY NAPKIN VENDOR SO SENSOR OPERATED SPL SOUND PRESSURE LEVEL SQ SQUARE SR SURFACE MOUNTED ELECTRICAL RACEWAY SS SOLID SURFACE SSA STORM SHELTER AREA SSM SOLID SURFACE SSS STAINLESS STEEL SHELF SST STAINLESS STEEL ST STONE ST STAIR STAGD STAGGERED STC SOUND TRANSMISSION CLASS STGR STAIR SUBFL SUBFLOOR SULPHUR SULPHUR SURF SURFACE SUSP SUSPENDED SVF SHEET VINYL FLOORING SVF SERVICE FIXTURE SVG SERVICE FIXTURE GROUP
---	--	---	--	---	--	---	--	---	--	---	--

GENERAL SYMBOLS



PROJECT DESCRIPTION

THE SCOPE OF THIS PROJECT IS AN INTERIOR IMPROVEMENT OF SELECT EXISTING RESTROOMS WITHIN AN EXISTING ELEMENTARY SCHOOL. WORK TO INCLUDE NEW WALLS, CEILINGS, DOORS, MILLWORK AND FINISHES, WITH SOME MECHANICAL, ELECTRICAL AND PLUMBING ADJUSTMENTS.

NO CHANGE TO OCCUPANCY TYPE.

TAB#: TABS2026004785

APPLICABLE CODES/GUIDELINES

APPLICABLE CODES & REGULATIONS:

GOVERNING AHJ: A. CITY OF HOUSTON
B. STATE OF TEXAS

A. CITY & STATE LEVEL GOVERNING CODES & REGULATIONS:

BUILDING: 2021 INTERNATIONAL BUILDING CODE (IBC)
2021 INTERNATIONAL EXISTING BUILDING CODE (IEBC)
ENERGY: 2021 INTERNATIONAL ENERGY CONSERVATION CODE (IECC)
FIRE PROTECTION: 2021 FIRE CODE (INTERNATIONAL FIRE CODE)
PLUMBING: 2021 UNIFORM PLUMBING CODE (UPC)
MECHANICAL: 2021 UNIFORM MECHANICAL CODE (UMC)
FUEL GAS: 2021 INTERNATIONAL FUEL GAS CODE (IFGC)
ELECTRICAL: 2023 INTERNATIONAL ELECTRICAL CODE (NEC)
ACCESSIBILITY: 2012 TEXAS ACCESSIBILITY STANDARDS (TAS)
TEA: TDA COMPLIANCE FOR ELIMINATION OF ARCHITECTURAL BARRIERS
TEXAS EDUCATION AGENCY (TEA) RULES APPLY FOR SCHOOL FACILITIES STANDARDS, INCLUDING SPACE REQUIREMENTS
HEALTH & SAFETY: TEXAS HEALTH AND SAFETY CODES GOVERNING HEALTH AND SANITATION REQUIREMENTS FOR SCHOOL FACILITIES, INCLUDING FOOD SERVICE AREAS AND WATER QUANTITY STANDARDS

CONSTRUCTION TYPE: I-A
OCCUPANCY GROUP: GROUP E
FIRE SPRINKLERED: YES
FIRE ALARM: YES

DEFERRED SUBMITTALS

MODIFICATIONS TO THE EXISTING SPRINKLERS AND FIRE ALARMS SHALL BE SUBMITTED AND PERMITTED SEPARATELY, PRIOR TO THEIR MODIFICATIONS.



PROJECT TEAM

CLIENT: ALIEF INDEPENDENT SCHOOL DISTRICT
4250 COOK ROAD
HOUSTON, TX 77072
ATTN: JESSE GONZALEZ; JESSE.GONZALEZ@ALIEFISD.NET

ARCHITECT: DLG GROUP
1000 LOUISIANA ST, SUITE 1100
HOUSTON, TX 77002
ATTN: AJ SUSTAITA; ASUSTAITA@DLRGROUP.COM

MEP: DBR INC
9990 RICHMOND AVE, SUITE 300
HOUSTON, TX 77042
ATTN: BRENT MOE; BMOE@DBRINC.COM

ARCHITECTURAL SYMBOLS



ALIEF ISD RESTROOM RENOVATION - PACKAGE I

BOONE ELEMENTARY SCHOOL

11400 BISSONNET STREET
HOUSTON, TEXAS 77099

ISSUE FOR BID & PERMIT

OCTOBER 31, 2025

INDEX OF DRAWINGS

GENERAL		MECHANICAL	
G0.1	COVER SHEET	M0.01	MECHANICAL SYMBOL LEGEND
		M0.11	MECHANICAL GENERAL NOTES & DETAILS
		M2.11	LEVEL 01 - MECHANICAL PLAN
		M3.01	LEVEL 01 - MECHANICAL PLAN - ENLARGED
		CODE	
CP1.1	CODE PLAN		
CP1.2	TEXAS ADA		
		ARCHITECTURAL	
A0.1	GENERAL NOTES, ARCHITECTURAL SYMBOLS & ABBREVIATIONS		
AD1.1	OVERALL - DEMOLITION PLAN		
AD2.1	ENLARGED DEMOLITION PLANS		
		PLUMBING	
A1.1	OVERALL - FLOOR PLAN		
A1.2	OVERALL - REFLECTED CEILING PLAN		
A2.0	ADA MOUNTING HEIGHTS	P0.01	PLUMBING SYMBOL LEGEND
A2.1	ENLARGED FLOOR PLANS AND ELEVATIONS	P0.11	PLUMBING GENERAL NOTES
A2.3	ENLARGED FLOOR PLANS AND ELEVATIONS	P2.11	LEVEL 01 - DEMOLITION PLUMBING PLAN
A2.4	ENLARGED FLOOR PLANS AND ELEVATIONS	P2.12	LEVEL 01 - PLUMBING PLAN
A2.5	ENLARGED FLOOR PLANS AND ELEVATIONS	P3.01	LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED
A2.6	ENLARGED FLOOR PLANS AND ELEVATIONS	P3.02	LEVEL 01 - PLUMBING PLAN - ENLARGED
A2.7	ENLARGED FLOOR PLANS AND ELEVATIONS	P6.01	PLUMBING SCHEDULES
		P6.01	PLUMBING DETAILS
		ELECTRICAL	
A3.0	TYPICAL REFLECTED CEILING PLAN RULES		
A8.2	DOOR & FRAME TYPE & SCHEDULE		
A12.01	FINISH SCHEDULES		
A14.1	SIGNAGE PLAN		
E0.01	ELECTRICAL SYMBOL LEGEND		
E0.11	ELECTRICAL GENERAL NOTES		
E1.11	LEVEL 01 - COMPOSITE DEMOLITION ELECTRICAL LIGHTING PLAN		
E1.12	LEVEL 01 - COMPOSITE DEMOLITION ELECTRICAL LIGHTING PLAN		
E2.11	LEVEL 01 - COMPOSITE DEMOLITION ELECTRICAL POWER PLAN		
E2.12	LEVEL 01 - COMPOSITE ELECTRICAL POWER PLAN		
E3.01	LEVEL 01 - DEMOLITION ELECTRICAL LIGHTING PLAN - ENLARGED		
E3.02	LEVEL 01 - DEMOLITION ELECTRICAL LIGHTING PLAN - ENLARGED		
E3.03	LEVEL 01 - ELECTRICAL LIGHTING PLAN - ENLARGED		
E3.04	LEVEL 01 - ELECTRICAL LIGHTING PLAN - ENLARGED		
E3.05	LEVEL 01 - DEMOLITION ELECTRICAL POWER PLAN - ENLARGED		
E3.06	LEVEL 01 - DEMOLITION ELECTRICAL POWER PLAN - ENLARGED		
E3.07	LEVEL 01 - ELECTRICAL POWER PLAN - ENLARGED		
E3.08	LEVEL 01 - ELECTRICAL POWER PLAN - ENLARGED		
E5.01	ELECTRICAL SCHEDULES		
E5.02	ELECTRICAL SCHEDULES		
E6.01	ELECTRICAL DETAILS		

DLR GROUP
© DLR Group

BOONE ELEMENTARY SCHOOL
ALIEF INDEPENDENT SCHOOL DISTRICT

11400 BISSONNET STREET
HOUSTON, TX 77099

ISSUE FOR BID & PERMIT
10-31-25
REVISIONS
1 12-17-25 COH COMMENTS
3 02-11-26 ISSUE FOR BID & PERMIT

39-25156-00
COVER SHEET

G0.1

Autodesk DocuSign 25156-00 Alief ISD restroom renovation 39-25156-00 Boone Elementary_AR_2024.rvt
2/6/2026 3:48:57 PM

ALIEF ISD RESTROOM RENOVATION - PACKAGE II

ELSIK HIGH SCHOOL


12601 HIGH STAR DRIVE
HOUSTON, TEXAS 77072

ISSUE FOR BID & PERMIT


OCTOBER 31, 2025



PROJECT LOCATION



KEY PLANS



SHEET INDEX & ISSUE SCHEDULE

GENERAL	PLUMBING
G0.1 COVER SHEET	P0.01 PLUMBING SYMBOL LEGEND P0.11 PLUMBING GENERAL NOTES P2.11 LEVEL 01 - DEMOLITION PLUMBING PLAN P2.12 LEVEL 01 - PLUMBING PLAN P2.21 LEVEL 02 - DEMOLITION PLUMBING PLAN P2.22 LEVEL 02 - PLUMBING PLAN P3.01 LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED P3.02 LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED P3.03 LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED P3.04 LEVEL 02 - DEMOLITION PLUMBING PLAN - ENLARGED P3.05 LEVEL 01 - PLUMBING PLAN - ENLARGED P3.06 LEVEL 01 - PLUMBING PLAN - ENLARGED P3.07 LEVEL 01 - PLUMBING PLAN - ENLARGED P3.08 LEVEL 02 - PLUMBING PLAN - ENLARGED P3.09 LEVEL 02 - PLUMBING PLAN - ENLARGED P5.01 PLUMBING SCHEDULES P5.01 PLUMBING DETAILS
ARCHITECTURAL	MECHANICAL
A0.1 GENERAL NOTES, ARCHITECTURAL SYMBOLS & ABBREVIATIONS	M0.01 MECHANICAL SYMBOL LEGEND M0.11 MECHANICAL GENERAL NOTES & DETAILS M2.11 LEVEL 01 - MECHANICAL PLAN M2.21 LEVEL 02 - MECHANICAL PLAN M3.11 LEVEL 01 - MECHANICAL PLAN - ENLARGED M3.12 LEVEL 01 - MECHANICAL PLAN - ENLARGED M3.13 LEVEL 02 - MECHANICAL PLAN - ENLARGED
A1.1 LEVEL 01 - OVERALL FLOOR PLAN A1.2 LEVEL 02 - OVERALL FLOOR PLAN A2.1 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.2 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.3 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.4 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.5 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.6 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.7 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.8 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.9 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.10 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.11 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.12 LEVEL 01 - ENLARGED FLOOR PLANS & ELEVATIONS A2.13 LEVEL 02 - ENLARGED FLOOR PLANS & ELEVATIONS A2.14 LEVEL 02 - ENLARGED FLOOR PLANS & ELEVATIONS A2.15 LEVEL 02 - ENLARGED FLOOR PLANS & ELEVATIONS A2.16 LEVEL 02 - ENLARGED FLOOR PLANS & ELEVATIONS A2.17 LEVEL 02 - ENLARGED FLOOR PLANS & ELEVATIONS A2.18 LEVEL 02 - ENLARGED FLOOR PLANS & ELEVATIONS A2.19 LEVEL 02 - ENLARGED FLOOR PLANS & ELEVATIONS	E0.01 ELECTRICAL SYMBOL LEGEND E0.11 ELECTRICAL GENERAL NOTES E1.11 LEVEL 01 - COMPOSITE ELECTRICAL LIGHTING PLAN - DEMO & NEW E1.21 LEVEL 02 - COMPOSITE ELECTRICAL LIGHTING PLAN - DEMO & NEW E2.11 LEVEL 01 - COMPOSITE ELECTRICAL POWER PLAN - DEMO & NEW E2.21 LEVEL 02 - COMPOSITE ELECTRICAL POWER PLAN - DEMO & NEW E3.01 LEVEL 01 - ELECTRICAL LIGHTING PLANS - ENLARGED E3.02 LEVEL 01 - ELECTRICAL LIGHTING PLANS - ENLARGED E3.03 LEVEL 01 - ELECTRICAL LIGHTING PLANS - ENLARGED E3.04 LEVEL 01 - ELECTRICAL LIGHTING PLANS - ENLARGED E3.05 LEVEL 01 - ELECTRICAL LIGHTING PLANS - ENLARGED E3.06 LEVEL 02 - ELECTRICAL LIGHTING PLANS - ENLARGED E3.07 LEVEL 02 - ELECTRICAL LIGHTING PLANS - ENLARGED E3.08 LEVEL 02 - ELECTRICAL LIGHTING PLANS - ENLARGED E3.09 LEVEL 02 - ELECTRICAL LIGHTING PLANS - ENLARGED E3.10 LEVEL 01 - ELECTRICAL POWER PLANS - ENLARGED E3.11 LEVEL 01 - ELECTRICAL POWER PLANS - ENLARGED E3.12 LEVEL 01 - ELECTRICAL POWER PLANS - ENLARGED E3.13 LEVEL 01 - ELECTRICAL POWER PLANS - ENLARGED E3.14 LEVEL 01 - ELECTRICAL POWER PLANS - ENLARGED E3.15 LEVEL 02 - ELECTRICAL POWER PLANS - ENLARGED E3.16 LEVEL 02 - ELECTRICAL POWER PLANS - ENLARGED E3.17 LEVEL 02 - ELECTRICAL POWER PLANS - ENLARGED E3.18 LEVEL 02 - ELECTRICAL POWER PLANS - ENLARGED E3.19 LEVEL 02 - ELECTRICAL POWER PLANS - ENLARGED E5.01 ELECTRICAL SCHEDULES & DETAILS E5.02 ELECTRICAL PANEL SCHEDULES E5.03 ELECTRICAL PANEL SCHEDULES
A8.2 DOOR & FRAME TYPE & SCHEDULE A12.01 FINISH SCHEDULES A14.1 SIGNAGE PLAN	

PROJECT INFORMATION

SCOPE OF WORK: THE SCOPE OF THIS PROJECT IS AN INTERIOR IMPROVEMENT OF SELECT EXISTING RESTROOMS AND REPLACING SELECT EXISTING DRINKING FOUNTAINS WITHIN AN EXISTING ELEMENTARY SCHOOL. WORK TO INCLUDE NEW WALLS, DOORS AND FINISHES, WITH SOME MECHANICAL ELECTRICAL AND PLUMBING ADJUSTMENTS.
NO CHANGE TO OCCUPANCY TYPE.

TABSS#: 2026004789

GOVERNING CODES & REGULATIONS:
GOVERNING AHJ: CITY OF HOUSTON STATE OF TEXAS
BUILDING CODE: 2021 INTERNATIONAL BUILDING CODE (W/ HOUSTON AMENDMENTS)
MECHANICAL CODE: 2021 UNIFORM MECHANICAL CODE (W/ HOUSTON AMENDMENTS)
ELECTRICAL CODE: 2023 NATIONAL ELECTRICAL CODE
PLUMBING CODE: 2021 UNIFORM PLUMBING CODE (W/ HOUSTON AMENDMENTS)
FIRE CODE: 2021 INTERNATIONAL FIRE CODE (W/ HOUSTON AMENDMENTS)
ENERGY CODE: 2021 INTERNATIONAL ENERGY CONSERVATION CODE (W/ HOUSTON AMENDMENTS)
ACCESSIBILITY: 2012 TEXAS ACCESSIBILITY STANDARDS

BUILDING OWNER: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefsd.net

PROJECT TEAM

CLIENT NAME: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefsd.net

OWNER'S REPRESENTATIVE: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefsd.net

ARCHITECT: DLR GROUP
1000 LOUISIANA STREET, SUITE 1100
HOUSTON, TX 77002
AJ SUSTATA
713.561.3925
asustata@dlrgroup.com

MEP ENGINEER: DBR INC.
9900 RICHMOND AVE, SUITE 300
HOUSTON, TX 77042
BRENT MOE
713.914.0888
bmoe@dbriinc.com

ALTERNATE PRICING

- X
- X

DEFERRED SUBMITTALS

MODIFICATIONS TO THE EXISTING SPRINKLERS AND FIRE ALARMS SHALL BE SUBMITTED AND PERMITTED SEPARATELY, PRIOR TO THEIR MODIFICATIONS.

ELSIK HIGH SCHOOL - RESTROOM RENOVATIONS
ALIEF INDEPENDENT SCHOOL DISTRICT
12601 HIGH STAR DRIVE
HOUSTON, TEXAS 77072

ISSUE FOR BID & PERMIT
10-31-25
REVISIONS

39-25156-00
COVER SHEET

G0.1


ALIEF ISD

HEFLIN ELEMENTARY SCHOOL - RESTROOM RENOVATIONS - PACKAGE II

3303 SYNOTT ROAD
HOUSTON, TEXAS 77082

ISSUE FOR BID & PERMIT
MAY 6, 2025

PROJECT LOCATION



PROJECT ADDRESS:
3303 SYNOTT ROAD
HOUSTON, TEXAS 77082



MAP DATA COPYRIGHT GOOGLE 2025

KEY PLANS



SHEET INDEX & ISSUE SCHEDULE

GENERAL		MECHANICAL	
G0.1	COVER SHEET	M0.01	MECHANICAL SYMBOL LEGEND
		M0.11	MECHANICAL GENERAL NOTES & DETAILS
		M2.11	LEVEL 01 - MECHANICAL PLAN
		M3.01	LEVEL 01 - MECHANICAL PLAN - ENLARGED
CODE			
CP.1	CODE PLAN		
CP.2	TEXAS ADA		
ARCHITECTURAL		PLUMBING	
A0.1	GENERAL NOTES, ARCHITECTURAL SYMBOLS & ABBREVIATIONS	P0.01	PLUMBING SYMBOL LEGEND
AD1.1	OVERALL - DEMOLITION PLAN	P0.11	PLUMBING GENERAL NOTES
AD2.1	ENLARGED DEMOLITION PLANS	P2.11	LEVEL 01 - DEMOLITION PLUMBING PLAN
A1.1	OVERALL - FLOOR PLAN	P2.12	LEVEL 01 - PLUMBING PLAN
A1.2	LEVEL 01 - OVERALL - REFLECTED CEILING PLAN	P3.01	LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED
A2.1	ENLARGED FLOOR PLANS & ELEVATIONS	P3.02	LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED
A2.3	ENLARGED FLOOR PLANS & ELEVATIONS	P3.03	LEVEL 01 - PLUMBING PLAN - ENLARGED
A2.4	ENLARGED FLOOR PLANS & ELEVATIONS	P3.04	LEVEL 01 - PLUMBING PLAN - ENLARGED
A2.5	ENLARGED FLOOR PLANS & ELEVATIONS	P4.01	PLUMBING RISER
A2.6	ENLARGED FLOOR PLANS & ELEVATIONS	P5.01	PLUMBING SCHEDULES
A2.7	ENLARGED FLOOR PLANS & ELEVATIONS	P6.01	PLUMBING DETAILS
A2.8	ENLARGED FLOOR PLANS & ELEVATIONS		
A2.9	ENLARGED FLOOR PLANS & ELEVATIONS		
A2.10	ENLARGED FLOOR PLANS & ELEVATIONS		
A3.0	TYPICAL REFLECTED CEILING PLAN RULES	ELECTRICAL	
A8.2	DOOR & FRAME TYPE & SCHEDULE	E0.01	ELECTRICAL SYMBOL LEGEND
A12.01	FINISH SCHEDULES	E0.11	ELECTRICAL GENERAL NOTES
A14.1	SIGNAGE PLAN	E1.11	LEVEL 01 - COMPOSITE DEMOLITION ELECTRICAL LIGHTING PLAN
		E1.12	LEVEL 01 - COMPOSITE ELECTRICAL LIGHTING PLAN
		E2.11	LEVEL 01 - COMPOSITE DEMOLITION ELECTRICAL POWER PLAN
		E2.12	LEVEL 01 - COMPOSITE ELECTRICAL POWER PLAN
		E3.01	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.02	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.03	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.04	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.05	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.06	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.07	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E5.01	ELECTRICAL SCHEDULES & DETAILS
		E5.02	ELECTRICAL SCHEDULES

PROJECT INFORMATION

SCOPE OF WORK: THE SCOPE OF THIS PROJECT IS AN INTERIOR IMPROVEMENT OF SELECT EXISTING RESTROOMS AND REPLACING SELECT EXISTING DRINKING FOUNTAINS WITHIN AN EXISTING ELEMENTARY SCHOOL. WORK TO INCLUDE NEW WALLS, DOORS, MILLWORK AND FINISHES, WITH SOME MECHANICAL, ELECTRICAL AND PLUMBING ADJUSTMENTS.
NO CHANGE TO OCCUPANCY TYPE.

TABS#: 2025018382

GOVERNING CODES & REGULATIONS:
GOVERNING AHJ: CITY OF HOUSTON STATE OF TEXAS
BUILDING CODE: 2021 INTERNATIONAL BUILDING CODE (W/ HOUSTON AMENDMENTS)
MECHANICAL CODE: 2021 UNIFORM MECHANICAL CODE (W/ HOUSTON AMENDMENTS)
ELECTRICAL CODE: 2023 NATIONAL ELECTRICAL CODE
PLUMBING CODE: 2021 UNIFORM PLUMBING CODE (W/ HOUSTON AMENDMENTS)
FIRE CODE: 2021 INTERNATIONAL FIRE CODE (W/ HOUSTON AMENDMENTS)
ENERGY CODE: 2021 INTERNATIONAL ENERGY CONSERVATION CODE (W/ HOUSTON AMENDMENTS)
ACCESSIBILITY: 2012 TEXAS ACCESSIBILITY STANDARDS

BUILDING OWNER: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
JESSE.GONZALEZ@ALIEFISD.NET

PROJECT TEAM

CLIENT NAME: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefisd.net

OWNER'S REPRESENTATIVE: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefisd.net

ARCHITECT: DLR GROUP
1000 LOUISIANA STREET, SUITE 1100
HOUSTON, TX 77002
AJ SUSTATA
713.561.3825
asustata@dlrgroup.com

MEP ENGINEER: DBR INC.
9900 RICHMOND AVE, SUITE 300
HOUSTON, TX 77042
BRENT MOE
713.914.0888
bmoe@dbrrinc.com

ALTERNATE PRICING

1 X
2 X

DEFERRED SUBMITTALS

NA

ALIEF ISD RESTROOM RENOVATION - PACKAGE I

REES ELEMENTARY SCHOOL


16305 KENSLEY DRIVE
HOUSTON, TEXAS 77082

ISSUE FOR BID & PERMIT
OCTOBER 31, 2025

PROJECT LOCATION



KEY PLANS



SHEET INDEX & ISSUE SCHEDULE

GENERAL		MECHANICAL	
G0.1	COVER SHEET	M0.01	MECHANICAL SYMBOL LEGEND
		M0.11	MECHANICAL GENERAL NOTES & DETAILS
		M2.11	LEVEL 01 - MECHANICAL PLAN
		M3.01	LEVEL 01 - MECHANICAL PLAN - ENLARGED
CODE			
CP1.1	CODE PLAN		
CP1.2	TEXAS ADA		
CP1.3	PLUMBING FIXTURE COUNT		
ARCHITECTURAL		PLUMBING	
A0.1	GENERAL NOTES, ARCHITECTURAL SYMBOLS & ABBREVIATIONS	P0.01	PLUMBING SYMBOL LEGEND
AD1.1	LEVEL 01 - DEMOLITION PLAN	P0.11	PLUMBING GENERAL NOTES
AD2.1	ENLARGED DEMOLITION PLAN	P2.11	LEVEL 01 - DEMOLITION PLUMBING PLAN
A1.1	OVERALL - FLOOR PLAN	P2.12	LEVEL 01 - PLUMBING PLAN
A1.2	OVERALL - REFLECTED CEILING PLAN	P3.01	LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED
A2.1	SCHEDULES	P3.02	LEVEL 01 - DEMOLITION PLUMBING PLAN - ENLARGED
A2.2	ENLARGED FLOOR PLANS	P3.03	LEVEL 01 - PLUMBING PLAN - ENLARGED
A2.3	ENLARGED FLOOR PLANS	P3.04	LEVEL 01 - PLUMBING PLAN - ENLARGED
A2.4	ENLARGED FLOOR PLANS	P5.01	PLUMBING SCHEDULES
A2.5	ENLARGED FLOOR PLANS	P6.01	PLUMBING DETAILS
A2.6	ENLARGED FLOOR PLANS		
A2.7	ENLARGED FLOOR PLANS		
A2.8	ENLARGED FLOOR PLANS		
A2.9	ENLARGED FLOOR PLANS		
A2.10	ENLARGED FLOOR PLANS		
A2.11	ENLARGED FLOOR PLANS		
A2.12	ENLARGED FLOOR PLANS		
A3.0	TYPICAL REFLECTED CEILING PLAN RULES	E0.01	ELECTRICAL SYMBOL LEGEND
A8.2	DOOR & FRAME TYPE & SCHEDULE	E0.11	ELECTRICAL GENERAL NOTES
A12.01	FINISH SCHEDULES	E1.11	LEVEL 01 - COMPOSITE ELECTRICAL LIGHTING PLAN - DEMO AND NEW
A14.1	SIGNAGE PLAN	E2.11	LEVEL 01 - COMPOSITE ELECTRICAL POWER PLAN - DEMO AND NEW
		E3.01	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.02	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.03	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.04	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.05	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E3.06	LEVEL 01 - ELECTRICAL PLANS - ENLARGED
		E5.01	ELECTRICAL SCHEDULES
		E5.02	ELECTRICAL SCHEDULES

PROJECT INFORMATION

SCOPE OF WORK: THE SCOPE OF THIS PROJECT IS AN INTERIOR IMPROVEMENT OF SELECT EXISTING RESTROOMS AND REPLACING SELECT EXISTING DRINKING FOUNTAINS WITHIN AN EXISTING ELEMENTARY SCHOOL. WORK TO INCLUDE NEW WALLS, DOORS, AND FINISHES, WITH SOME MECHANICAL, ELECTRICAL AND PLUMBING ADJUSTMENTS.
NO CHANGE TO OCCUPANCY TYPE.

TABS#: TABS2026004777

GOVERNING CODES & REGULATIONS:
GOVERNING AHJ: CITY OF HOUSTON STATE OF TEXAS
BUILDING CODE: 2021 INTERNATIONAL BUILDING CODE (W/ HOUSTON AMENDMENTS)
MECHANICAL CODE: 2021 UNIFORM MECHANICAL CODE (W/ HOUSTON AMENDMENTS)
ELECTRICAL CODE: 2023 NATIONAL ELECTRICAL CODE (W/ HOUSTON AMENDMENTS)
PLUMBING CODE: 2021 UNIFORM PLUMBING CODE (W/ HOUSTON AMENDMENTS)
FIRE CODE: 2021 INTERNATIONAL FIRE CODE (W/ HOUSTON AMENDMENTS)
ENERGY CODE: 2021 INTERNATIONAL ENERGY CONSERVATION CODE (W/ HOUSTON AMENDMENTS)
ACCESSIBILITY: 2012 TEXAS ACCESSIBILITY STANDARDS

BUILDING OWNER: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
JESSE.GONZALEZ@ALIEFISD.NET

PROJECT TEAM

CLIENT NAME: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefisd.net

OWNER'S REPRESENTATIVE: ALIEF ISD ADMINISTRATION BUILDING
4250 COOK ROAD
HOUSTON, TX 77072
JESSE GONZALEZ
281.498.8110 EXT 29582
jesse.gonzalez@aliefisd.net

ARCHITECT: DLR GROUP
1000 LOUISIANA STREET, SUITE 1100
HOUSTON, TX 77002
AJ SUSTATA
713.561.3825
asustata@dlrgroup.com

MEP ENGINEER: DBR INC.
9900 RICHMOND AVE, SUITE 300
HOUSTON, TX 77042
BRENT MOE
713.974.0888
bmoe@dbrrinc.com

ALTERNATE PRICING

1 X
2 X

DEFERRED SUBMITTALS

MODIFICATIONS TO THE EXISTING SPRINKLERS AND FIRE ALARMS SHALL BE SUBMITTED AND PERMITTED SEPARATELY, PRIOR TO THEIR MODIFICATIONS.

