



## Addendum 03

### DATE

August 11, 2025

### ADDENDUM NO.

03

**PROJECT** 250119.000 | GPISD- NS Snr HS and Cobb 6th-HVAC Upgrades

The work described herein shall be added to the scope of work defined by the contract documents or it shall modify the scope of work defined by the contract documents as described. This work shall become a part of the contract documents by addendum.

### DRAWINGS

#### NORTH SHORE SENIOR HIGH SCHOOL

##### Item 01      **General Mechanical Scope Note**

- A.      Keyed note M4.3 (Typ. for all instances): Clarified blower wheel assembly includes the motor for existing AHU refurbishment scope. Keyed-note M4.3 now reads:

“EXISTING AIR HANDLING UNIT TO REMAIN. BLOWER WHEEL ASSEMBLY (INCLUDING MOTOR) AND BEARINGS TO BE REPLACED WITH NEW. PROVIDE NEW FLEX BOOTS, MATCH SIZE OF EXISTING FLEX BOOT. TYPICAL TO ALL EXISTING AIR HANDLING UNITS UNLESS NOTED OTHERWISE.

##### Item 02      **Sheet MN7.04 – MECHANICAL CONTROL DIAGRAMS.**

- A.      Removed packaged RTU sequence of operations and sheet in its entirety. RTU to have BACnet interface and run on internal controls.