



MORE THAN ARCHITECTS

ADDENDUM

NO. 1

TO THE DRAWINGS AND THE PROJECT MANUAL

PROJECT NAME: AR Turner Elementary School Classroom Expansion

CLIENT NAME: Willis Independent School District

LOCATION: Willis, Texas

PROJECT NUMBER: 01989-06-01

PROPOSAL DATE: Thursday, July 30, 2026, at 3:00 p.m.

ADDENDUM DATE: Monday, July 13, 2026

For additional information regarding this project, contact Matthew Gvist at matt.gvist@huckabee-inc.com or 281.380.0863



THIS ADDENDUM INCLUDES:

Civil Items	0 Pages
Landscape Items	0 Pages
Structural Items	0 Pages
Architectural Items	2 Pages
Plumbing Items	0 Pages
Mechanical Items	0 Pages
Electrical Items	0 Pages
Technology Items	0 Pages

AND ALL ATTACHED REVISED DRAWING REFERENCES IN THE ADDENDUM

Huckabee

a MOREgroup brand

Project Name: AR Turner ES Classroom Addition
Client: Willis Independent School District
Willis, Texas
Project Number: 01989-06-01



07/13/2026

ARCHITECTURAL ITEMS FOR ADDENDUM NO. 1

NOTICE TO PROPOSERS:

- A. This Addendum shall be considered part of the contract documents for the above-mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original contract documents, this Addendum shall govern and take precedence.
- B. Proposers are hereby notified that they shall make any necessary adjustments in their estimate on account of this Addendum. It will be construed that each Proposer's proposal is submitted with full knowledge of all modifications and supplemental data specified therein. Acknowledge receipt of this addendum in the space provided on the proposal form. Failure to do so may subject Proposer to disqualification.

REFERENCE IS MADE TO THE DRAWINGS AND THE PROJECT MANUAL AS NOTED:

PROJECT MANUAL:

AD No 1, Arch. Item 1: To the Project Manual, Sections as listed below, Part 2 – Products;

Products listed herein are considered acceptable for conformance with the design concept of the project and general compliance with the information given in the contract documents. The manufacturer, supplier and installer are responsible for meeting all requirements given in the contract documents unless specifically noted in the written approval.

- 1) To Section 07 5400, "THERMOPLASTIC MEMBRANE ROOFING"
ADD Elevate: www.elevatecommercialbp.com as an approved manufacturer.

AD No 1, Arch. Item 2: To the Project Manual, Section 00 4393 "PROPOSAL SUBMITTAL CHECKLIST"

To paragraph 1.02, **REVISE** the date and time as follows: "Thursday, July 30, 2026, no later than 3:00 P.M."

AD No 1, Arch. Item 3: To the Project Manual, Section 00 4393 "PROPOSAL SUBMITTAL CHECKLIST"

To paragraph 1.03, **REVISE** the date and time as follows: "Thursday, July 30, 2026, no later than 3:00 P.M."

AD No 1, Arch. Item 4: To the Project Manual, Section 07 5400 "THERMOPLASTIC MEMBRANE ROOFING"

To paragraph 3.02, **DELETE** the following:

- C. Electronic Leak Detection (ELD) Testing: Test roofing areas for leaks using ELD method that locates discontinuities in membrane roofing in accordance with ASTM D8231.
 1. Testing agency to provide training certification from testing equipment manufacturer to ensure that technician performing ELD testing is currently certified in accordance with training program of testing equipment manufacturer.

WE ARE MORE.

Architectural Items For
Addendum No. #1
Page 1 of 2

Huckabee

a **MORE**group brand

Project Name: AR Turner ES Classroom Addition
Client: Willis Independent School District
Willis, Texas
Project Number: 01989-06-01

2. Manufacturers:
 - a. Detec Systems; Electronic Leak Detection Quality Control Testing - IntegriScan: www.detecsystems.com/#sle.
 - b. IR Analyzers / Vector Mapping; High Voltage ELD: www.iranalyzers.com/#sle.
 - c. Substitutions: See Section 016000 - Product Requirements.

DRAWINGS:

END OF ARCHITECTURAL ADDENDUM

WE ARE **MORE**.

Architectural Items For
Addendum No. #1
Page 2 of 2